



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

Docket No.: 50-339

Mr. W. L. Proffitt  
Senior Vice President  
Power Operations  
Virginia Electric and Power Company  
P. O. Box 26666  
Richmond, Virginia 23261

Dear Mr. Proffitt:

SUBJECT: IMPLEMENTATION OF THE RECOMMENDATIONS OF NUREG-0660, "ENHANCEMENT OF ONSITE EMERGENCY DIESEL GENERATOR RELIABILITY" - NORTH ANNA POWER STATION, UNIT 2

Currently the reliability of diesel generators requires demonstration by performance of the preoperational testing specifications of Regulatory Guide 1.108. In addition, Technical Specifications include the periodic testing provisions of Regulatory Guide 1.108 for continuous demonstration of diesel generator reliability.

As part of our ongoing long-term activities concerning diesel generator reliability, in a letter dated April 18, 1979, we transmitted the report NUREG-0660 "Enhancement of Onsite Emergency Diesel Generator Reliability" for your information and comments. We stated that we would review the report and evaluate each recommendation for its applicability to all operating license applications.

To assist us in our evaluation of this matter, we request you provide your views and comments on the specific recommendations in NUREG-0660 as described in the enclosure to this letter. If the requested information is already available to us, a reference to a FSAR section or other documentation which contains the requested information would be sufficient.

The results of our review of this matter will identify what changes to current requirements may be appropriate and the associated implementation schedule.

90002154

80 01040

321


A

Mr. W. L. Proffitt

- 2 -

In order to include consideration of your comments into our review, please reply by January 31, 1980.

Sincerely,



Olan D. Parr, Chief  
Light Water Reactors, Branch No. 3  
Division of Project Management

Enclosure:  
As Stated

cc: See Next Page

90002155

Mr. W. L. Proffitt

cc: Mr. Anthony Gambaradella  
Office of the Attorney General  
11 South 12th Street - Room 308  
Richmond, Virginia 23219

Richard M. Foster, Esq.  
Musick, Williamson, Schwartz  
Leavenworth & Cope, P. C.  
P. O. Box 4579  
Boulder, Colorado 80306

Michael W. Maupin, Esq.  
Hunton, Williams, Gay & Gibson  
P. O. Box 1535  
Richmond, Virginia 23212

Mrs. June Allen  
412 Owens Drive  
Huntsville, Alabama 35801

Mrs. James Torson  
501 Leroy  
Socorro, New Mexico 87801

Mrs. Margaret Dietrich  
Route 2, Box 568  
Gordonsville, Virginia 22942

William H. Rodgers, Jr., Esq.  
Georgetown University Law Center  
600 New Jersey Avenue, N. W.  
Washington, D. C. 20001

Mr. Peter S. Hepp  
Executive Vice President  
Sun Shipping & Dry Dock Company  
P. O. Box 540  
Chester, Pennsylvania 19013

Mr. R. B. Briggs  
Associate Director  
110 Evans Lane  
Oak Ridge, Tennessee 37830

Clarence T. Kipps, Jr., Esq.  
1700 Pennsylvania Avenue, N.W.  
Washington, D. C. 20006

Carroll J. Savage, Esq.  
1700 Pennsylvania Avenue, N.W.  
Washington, D. C. 20006

Mr. James C. Dunstan  
State Corporation Commission  
Commonwealth of Virginia  
Blandon Building  
Richmond, Virginia 23209

Alan S. Rosenthal, Esq.  
Atomic Safety and Licensing Appeal Board  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Michael C. Farrar, Esq.  
Atomic Safety and Licensing Appeal Board  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. John H. Buck  
Atomic Safety and Licensing Appeal Board  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Atomic Safety and Licensing Board Panel  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mr. Michael S. Kidd  
U.S. Nuclear Regulatory Commission  
P. O. Box 123  
Spotsylvania, Virginia 22553

Dr. Paul W. Purdom  
Department of Civil Engineering  
Drexel University  
Philadelphia, Pennsylvania 19104

90002156

Mr. W. L. Proffitt

cc: Dr. Lawrence R. Quarles  
Apartment No. 51  
Kendal-at-Longwood  
Kennett Square, Pennsylvania 19348

Mr. Irwin B. Kroot  
Citizens Energy Forum  
P. O. Box 138  
McLean, Virginia 22101

James B. Dougherty, Esq.  
Potomac Alliance  
1416 S Street, N.W.  
Washington, D. C. 20009

90002157

REQUEST FOR ADDITIONAL INFORMATION

NORTH ANNA POWER STATION, UNIT 2

DOCKET NO. 50-339

8.0 Electrical Systems

- 8.14 Provide a discussion of the measures that have been taken in the design of the standby diesel generator air starting system to preclude the fouling of the air start valve or filter with moisture and contaminants such as oil carryover and rust. ( 9.5.6, Part III, item 1).

90002158

- 8.15 Experience at some operating plants has shown that diesel engines have failed to start due to accumulation of dust and other deleterious material on electrical equipment associated with starting of the diesel generators (e.g., auxiliary relay contacts, control switches - etc.). Describe the provisions that have been made in your diesel generator building design, electrical starting system, and combustion air and ventilation air intake design(s) to preclude this condition to assure availability of the diesel generator on demand.

Also describe under normal plant operation what procedure(s) will be used to minimize accumulation of dust in the diesel generator room; specifically address concrete dust control. In your response also consider the condition when Unit 1 is in operation and Unit 2 is under construction (abnormal generation of dust).

90002159

POOR ORIGINAL

- 8.16 The diesel generators are required to start automatically on loss of all offsite power and in the event of a LOCA. The diesel generator sets should be capable of operation at less than full load for extended periods without degradation of performance or reliability. Should a LOCA occur with availability of offsite power, discuss the design provisions and other parameters that have been considered in the selection of the diesel generators to enable them to run unloaded (on standby) for extended periods without degradation of engine performance or reliability. Expand your PSAR/FSAR to include and explicitly define the capability of your design with regard to this requirement. (SRP 9.5.5, Part III, Item 7).

90002160

POOR ORIGINAL

- 8.17 Section 9.5.4.1 emergency diesel engine fuel oil storage and transfer system (EDEFSS) does not specifically reference ANSI Standard N195 "Fuel Oil Systems for Standby Diesel Generators". Indicate if you intend to comply with this standard in your design of the EDEFSS; otherwise provide justification for non-compliance. (SRP 9.5.4, Rev. 1, Part II, item 12).
- 8.18 Assume an unlikely event has occurred requiring operation of a diesel generator for a prolonged period that would require replenishment of fuel oil without interrupting operation of the diesel generator. What provision will be made in the design of the fuel oil storage fill system to minimize the creation of turbulence of the sediment in the bottom of the storage tank. Stirring of this sediment during addition of new fuel has the potential of causing the overall quality of the fuel to become unacceptable and could potentially lead to the degradation or failure of the diesel generator.
- 8.19 Discuss the precautionary measures that will be taken to assure the quality and reliability of the fuel oil supply for emergency diesel generator operation. Include the type of fuel oil, impurity and quality limitations as well as diesel index number or its equivalent, cloud point, entrained moisture, sulfur, particulates and other deleterious insoluble substances; procedure for testing newly delivered fuel, periodic sampling and testing of on-site fuel oil (including interval between tests), interval of time between periodic removal of condensate from fuel tanks and periodic system inspection. In your discussion include reference to industry (or other) standard which will be followed to assure a reliable fuel oil supply to the emergency generators. (SRP 9.5.4, Part III, items 3 and 4).

90002161

POOR ORIGINAL



8.20 Operating experience has shown that accumulation of water in the starting air system has been one of the most frequent causes of diesel engine failure to start on demand. Condensation of entrained moisture in compressed air lines leading to control and starting air valves, air start motors, and condensation of moisture on the working surfaces of these components has caused rust, scale and water itself to build up and score and jam the internal working parts of these vital components thereby preventing starting of the diesel generators.

In the event of loss of offsite power the diesel generators must function since they are vital to the safe shutdown of the reactor(s). Failure of the diesel engines to start from the effects of moisture condensation in air starting systems and from other causes have lowered their operational reliability to substantially less than the desired reliability of 0.92 as specified in Branch Technical Position ICSS (ESB) 2 "Diesel Generator Reliability Testing" and Regulatory Guide 1.108 "Periodic Testing of Diesel Generator Units Used as Onsite Electric Power Systems at Nuclear Power Plants."

In an effort toward improving diesel engine starting reliability NUREG-0660 indicates that compressed air starting system designs include air dryers for the removal of entrained moisture. The two air dryers most commonly used are the dessicant and refrigerant

POOR ORIGINAL

90002162

types. Of these two types, the refrigerant type is the one most suited for this application and therefore is preferred. Starting air should be dried to a dew point of not more than 50°F when installed in a normally controlled 70°F environment, otherwise the starting air dew point should be controlled to at least 10°F less than the lowest expected ambient temperature.

Describe your diesel engine air starting system and indicate how your system meets the recommendation stated in NUREG-0660. If there are any differences between your design and the recommendations of NUREG-0660, provide justification for your design or plans for implementation.

90002163

POOR ORIGINAL

8.21 Operating experience at certain nuclear power plants which have two cycle turbocharged diesel engines manufactured by the Electromotive Division (EMD) of General Motors driving emergency generators have experienced a significant number of turbocharger mechanical gear drive failures. The failures have occurred as the result of running the emergency diesel generators at no load or light load conditions for extended periods. No load or light load operation could occur during periodic equipment testing or during accident conditions with availability of offsite power. When this equipment is operated under no load conditions insufficient exhaust gas volume is generated to operate the turbocharger. As a result the turbocharger is driven mechanically from a gear drive in order to supply enough combustion air to the engine to maintain rated speed. The turbocharger and mechanical drive gear normally supplied with these engines are not designed for standby service encountered in nuclear power plant application where the equipment may be called upon to operate at no load or light load condition and full rated speed for a prolonged period. The EMD equipment was originally designed for locomotive service where no load speeds for the engine and generator are much lower than full load speeds. The locomotive turbocharged diesel hardly ever runs at full speed except at full load. The EMD has strongly recommended to warn of this diesel engine design against operation at no load or light load conditions at full rated speed for extended periods because of the short life expectancy of the turbocharger mechanical gear drive unit normally

90002164

POOR ORIGINAL

furnished. No load or light load operation also causes general deterioration in any diesel engine.

To cope with the severe service the equipment is normally subjected to and in the interest of reducing failures and increasing the availability of their equipment EMD has developed a heavy duty turbocharger drive gear unit that can replace existing equipment. This is available as a replacement kit, or engines can be ordered with the heavy duty turbocharger drive gear assembly.

To assure optimum availability of emergency diesel generators on demand, Applicant's who have on order or intend to order emergency generators driven by two cycle diesel engines manufactured by EMD should be provided with the heavy duty turbocharger mechanical drive gear assembly as recommended by EMD for the class of service encountered in nuclear power plants. Confirm your compliance with this requirement.

90002165

POOR ORIGINAL

8.22 Provide a detail discussion (or plan) of the level of training proposed for your operators, maintenance crew, quality assurance, and supervisory personnel responsible for the operation and maintenance of the emergency diesel generators. Identify the number and type of personnel that will be dedicated to the operations and maintenance of the emergency diesel generators and the number and type that will be assigned from your general plant operations and maintenance groups to assist when needed.

In your discussion identify the amount and kind of training that will be received by each of the above categories and the type of ongoing training program planned to assure optimum availability of the emergency generators.

Also discuss the level of education and minimum experience requirements for the various categories of operations and maintenance personnel associated with the emergency diesel generators.

9C002166

POOR ORIGINAL

8.23

Several fires have occurred at some operating plants in the area of the diesel engine exhaust manifold and inside the turbocharger housing which have resulted in equipment unavailability. The fires were started from lube oil leaking and accumulating on the engine exhaust manifold and accumulating and igniting inside the turbocharger housing. Accumulation of lube oil in these areas, on some engines, is apparently caused from an excessively long prelube period, generally longer than five minutes, prior to manual starting of a diesel generator. This condition does not occur on an emergency start since the prelube period is minimal.

When manually starting the diesel generators for any reason, to minimize the potential fire hazard and to improve equipment availability, NUREG-0660 recommends that the prelube period should be limited to a maximum of three to five minutes unless otherwise recommended by the diesel engine manufacturer.

Provide the prelube time interval your diesel engine will be exposed to prior to manual start and if this interval does not agree with the recommendations of NUREG-0660 provide justification why your interval time is acceptable.

90002167

POOR ORIGINAL

8.24 An emergency diesel generator unit in a nuclear power plant is normally in the ready standby mode unless there is a loss of offsite power, an accident, or the diesel generator is under test. Long periods on standby have a tendency to drain or nearly empty the engine lube oil piping system. On an emergency start of the engine as much as 5 to 14 or more seconds may elapse from the start of cranking until full lube oil pressure is attained even though full engine speed is generally reached in about five seconds. With an essentially dry engine, the momentary lack of lubrication at the various moving parts may damage bearing surfaces producing incipient or actual component failure with resultant equipment unavailability.

The emergency condition of readiness requires this equipment to attain full rated speed and enable automatic sequencing of electric load within ten seconds. For this reason, and to improve upon the availability of this equipment on demand, it is necessary to establish as quickly as possible an oil film in the wearing parts of the diesel engine. Lubricating oil is normally delivered to the engine wearing parts by one or more engine driven pump(s). During the starting cycle the pump(s) accelerates slowly with the engine and may not supply the required quantity of lubricating oil where needed fast enough. To remedy this condition, as a minimum, an electrically driven lubricating oil pump, powered from a reliable DC power supply, should be installed in the lube oil system to operate in parallel with the engine

POOR ORIGINAL

90002168

driven main lube pump. The electric driven prelube pump should operate only during the engine cranking cycle or until satisfactory lube oil pressure is established in the engine main lube distribution header. The installation of this prelube pump should be coordinated with the respective engine manufacturer. Some diesel engines include a lube oil circulating pump as an integral part of the lube oil preheating system which is in use while the diesel engine is in the standby mode. In this case an additional prelube oil pump may not be needed.

Indicate whether your design includes an electric prelube oil pump. If your design does not include this pump, provide justification why it is not necessary.

POOR ORIGINAL

90002169



8.25 Periodic testing and test loading of an emergency diesel generator in a nuclear power plant is a necessary function to demonstrate the operability, capability and availability of the unit on demand. Periodic testing coupled with good preventive maintenance practices will assure optimum equipment readiness and availability on demand. This is the desired goal.

To achieve this optimum equipment readiness status, NUREG 0660 recommends the following:

1. The equipment should be tested with a minimum loading of 25 percent of rated load. No load or light load operation will cause incomplete combustion of fuel resulting in the formation of gum and varnish deposits on the cylinder walls, intake and exhaust valves, pistons and piston rings, etc., and accumulation of unburned fuel in the turbocharger and exhaust system. The consequences of no load or light load operation are potential equipment failure due to the gum and varnish deposits and fire in the engine exhaust system.
2. Periodic surveillance testing should be performed in accordance with the applicable NRC guidelines (R.d. 1.10B), and with the recommendations of the engine manufacturer. Conflicts between any such recommendations and the NRC guidelines, particularly with respect to test frequency, loading and duration, should be identified and justified.

POOR ORIGINAL

90002170

3. Preventive maintenance should go beyond the normal routine adjustments, servicing and repair of components when a malfunction occurs. Preventive maintenance should encompass investigative testing of components which have a history of repeated malfunctioning and require constant attention and repair. In such cases consideration should be given to replacement of those components with other products which have a record of demonstrated reliability, rather than repetitive repair and maintenance of the existing components. Testing of the unit after adjustments or repairs have been made only confirms that the equipment is operable and does not necessarily mean that the root cause of the problem has been eliminated or alleviated.
4. Upon completion of repairs or maintenance and prior to an actual start, run, and load test a final equipment check should be made to assure that all electrical circuits are functional, i.e., fuses are in place, switches and circuit breakers are in their proper position, no loose wires, all test leads have been removed, and all valves are in the proper position to permit a manual start of the equipment. After the unit has been satisfactorily started and load tested, return the unit to ready automatic standby service and under the control of the control room operator.

Provide a discussion of whether the recommendations of NUREG-0660 have been implemented in the emergency diesel generator system design and how they will be considered when the plant is in commercial operation, i.e., by what means will the above requirements be enforced.

POOR ORIGINAL

00002171

8.26 The availability on demand of an emergency diesel generator is dependent upon, among other things, the proper functioning of its controls and monitoring instrumentation. This equipment is generally panel mounted and in some instances the panels are mounted directly on the diesel generator skid. Major diesel engine damage has occurred at some operating plants from vibration induced wear on skid mounted control and monitoring instrumentation. This sensitive instrumentation is not made to withstand and function accurately for prolonged periods under continuous vibrational stresses normally encountered with internal combustion engines. Operation of sensitive instrumentation under this environment rapidly deteriorates calibration, accuracy and control signal output.

Therefore, except for sensors and other equipment that must be directly mounted on the engine or associated piping, NUREG-0660 recommends that the controls and monitoring instrumentation be installed on a free standing floor mounted panel separate from the engine skids, and located on a vibration free floor area or equipped with vibration mounts.

Provide a description of how the controls and monitoring systems are installed and indicate how your design addresses the recommendations of NUREG-0660.

POOR ORIGINAL

90002172

- 8.27 Experience at operating plants has shown that a diesel engine that is provided with an engine cooling water temperature control system employing a 3-way bypass-type thermostatically controlled valve have demonstrated consistent trouble free operation over engines provided with other methods of temperature control such as shutter controls on radiators. Does your system employ a water thermostat of the 3-way or bypass-type which splits the water flow so only as much water passes through the cooler or radiator as needed to maintain the proper outlet temperature? If your engine cooling water system does not use a 3-way valve, describe your installed system and justify its design as opposed to a design employing a 3-way valve.

90002173