

Docket No. 50-336  
B14318

Attachment 1

Millstone Nuclear Power Station, Unit No. 2

Proposed Revision to Technical Specification  
Engineered Safety Feature Actuation System Instrumentation  
Proposed Changed Page

December 1992

9212110118 921208  
PDR ADOCK 03000336  
P PDR

TABLE 3.3-3 (Continued)

- ACTION 3 - With one or more channels inoperable, operation may continue provided the containment purge valves are maintained closed.
- ACTION 4 - With the number of OPERABLE channels one less than the Minimum Number of Channels, place the inoperable channel in the bypassed condition and restore the channel to OPERABLE status within 48 hours or be in COLD SHUTDOWN within the next 36 hours. No other channels shall be removed from service for surveillance testing during this ACTION STATEMENT.