

NOTICE OF VIOLATION

Commonwealth Edison Company
Zion Station, Units 1 and 2

Docket Nos. 50-295; 50-304
Licenses No. DPR-39; DPR-48

During an NRC inspection conducted on October 5 through 29, 1992, two violations of NRC requirements were identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C, the violations are listed below:

1. 10 CFR 50.59 (b)(1) requires that records of changes made in the facility as described in the safety analysis report must include a written safety evaluation which provides the bases for the determination that the change does not involve an unreviewed safety question.

Contrary to the above, the 10 CFR 50.59 safety evaluation for temporary alteration 90-053, "Bit Outlet Valve Leakage Reroute To RCDT", dated June 9, 1990, was not adequate to provide a basis for the determination that this temporary alteration did not involve an unreviewed safety question.

This is a severity level IV violation (Supplement I)

2. 10 CFR 50, Appendix B, Criterion XI, Test Control, states in part, that a test program shall be established to assure that all testing required to demonstrate that structures, systems, and components will perform satisfactorily in service is identified and performed in accordance with written test procedures.


Contrary to the above, on March 22, 1991, adequate testing required to demonstrate that components perform satisfactorily was not performed following maintenance on valve 1RH-8701. The maintenance work disabled a valve interlock which was not verified by post-maintenance testing.

This is a Severity Level IV violation (Supplement I)

Pursuant to the provisions of 10 CFR 2.201, Commonwealth Edison Company is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington D.C. 20555 with a copy to the U.S. Nuclear Regulatory Commission, Region III, 799 Roosevelt Road, Glen Ellyn, Illinois, 60137, and a copy to the NRC Resident Inspector at the Zion Station within 30 days of the date of the letter transmitting this Notice of Violation (Notice).

This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. If an adequate reply is not received within the time specified in this Notice, an order or a demand for information may be issued as to why the license should not be modified, suspended, or revoked, or why such other action as may be proper should not be taken. Where good cause is shown, consideration will be given to extending the response time.

Dated at Glen Ellyn, Illinois
this 4th day of December, 1992



H. J. Miller, Director
Division of Reactor Safety