

FIRE PROTECTION LICENSE CONDITION

1. The licensee shall implement and maintain in effect all provisions of the approved fire protection plan, as approved on (Date of Amendment), and subject to the provisions of 2 and 3 below.
2. The licensee may make no change to the approved fire protection plan which would decrease the level of fire protection in the plant without prior approval of the Commission. To make such a change the licensee must submit an application for license amendment pursuant to 10 CFR 50.90.
3. The licensee may make changes to the approved fire protection plan which do not decrease the level of fire protection without prior Commission approval provided such changes do not otherwise involve a change in a license condition or technical specification or result in an unreviewed safety question (see 10 CFR 50.59). The licensee shall maintain, in an auditable form, a current record of all such changes, including an analysis of the effects of the change on the fire protection program, and shall make such records available to NRC inspectors upon request. All changes to the approved plan shall be reported annually to the Director of the Office of Nuclear Reactor Regulation, along with the FSAR revisions required by 10 CFR 50.71(e).

8506120116 850607  
PDR ADOCK 05000302  
P PDR