



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

November 17, 1979

Docket No. 50-271

Mr. Robert H. Groce
Licensing Engineer
Yankee Atomic Electric Company
20 Turnpike Road
Westboro, Massachusetts 01581

Dear Mr. Groce:

We are reviewing your submittal dated January 9, 1979 in response to our letter dated November 29, 1978 concerning containment purging. As a result of our review to date, we have determined that the additional systems information requested in the enclosure is necessary in order for us to complete our long term containment purge and venting system safety evaluation. Please provide answers to these questions within 45 days of receipt of this letter.

We have not yet completed our review of the mechanical, electrical and instrumentation aspects of containment purge, but we expect that we may have additional questions for you in these areas.

Sincerely,

Thomas X. Ippolito
Thomas X. Ippolito, Chief
Operating Reactors Branch #3
Division of Operating Reactors

Enclosure:
Request for Additional
Information

cc w/enclosure:
See page 2

90022294

8001110 680

Mr. Robert H. Groce
Yankee Atomic Electric Company

- 2 -

POOR ORIGINAL

cc:

Ms. J. M. Abbey
Vermont Yankee Nuclear Power
Corporation
77 Grove Street
Rutland, Vermont 05701

Mr. Donald E. Vandenburg,
Vice President
Vermont Yankee Nuclear Power
Corporation
Turnpike Road, Route 9
Westboro, Massachusetts 01581

John A. Ritsher, Esquire
Ropes & Gray
225 Franklin Street
Boston, Massachusetts 02110

Laurie Burt
Assistant Attorney, General
Environmental Protection Division
Attorney General's Office
One Ashburton Place, 19th Floor
Boston Massachusetts 02108

Richard E. Ayres, Esquire
Natural Resources Defense Counsel
917 15th Street, N. W.
Washington, D. C. 20005

Honorable M. Jerome Diamond
Attorney General
State of Vermont
109 State Street
Pavilion Office Building
Montpelier, Vermont 05602

Anthony Z. Roisman
Natural Resources Defense Council
917 15th Street, N. W.
Washington, D. C. 20005

John P. Stanton, Director
Radiation Control Agency
Hazen Drive
Concord, New Hampshire 03301

John W. Stevens
Conservation Society of
Southern Vermont
P. O. Box 256
Townshend, Vermont 05353

Dr. Mars Longley, Director
Division Occupational Health
32 Spaulding Street
Barre, Vermont 05641

New England Coalition on Nuclear
Pollution
Hill and Dale Farm
West Hill - Faraway Road
Putney, Vermont 05346

Public Service Board
State of Vermont
120 State Street
Montpelier, Vermont 05602

W. F. Conway, Plant Superintendent
Vermont Yankee Nuclear Power
Corporation
P. O. Box 157
Vernon, Vermont 05354

Mr. Charles Sheketoff
Assistant Director
Vermont Public Interest
Research Group, Inc.
26 State Street
Montpelier, Vermont 05602

Brooks Memorial Library
224 Main Street
Brattleboro, Vermont 05301

90022295

REQUEST FOR ADDITIONAL INFORMATION
FOR CONTAINMENT PURGE SYSTEM AND
CONTAINMENT VENTING SYSTEM FOR
VERMONT YANKEE NUCLEAR POWER PLANT

DOCKET NO. 50-271

POOR ORIGINAL

1. With regard to the containment purge and venting system, provide the following information:
 - a. Discuss the provisions made to ensure that isolation valve closure will not be prevented by debris which could potentially become entrained in the escaping air and steam.
 - b. Discuss the provisions made for testing the availability of the isolation function and the leakage rate of the isolation valves, individually, during reactor operation.
 - c. Quantify the amount of containment atmosphere released through the purge and vent isolation valves for a spectrum of break sizes during the maximum closure time allowed in your Technical Specifications.
 - d. Provide an analysis to demonstrate the acceptability of the provisions made to protect structures and safety-related equipment; e.g., fans, filters, and ductwork, located beyond the purge system isolation valves against loss of function from the environment created by the escaping air and steam.
 - e. For the containment purge isolation valves, specify the differential pressure across the valve for which the maximum leak rate occurs. Further, provide test results (e.g., from vendor tests of leakage rate versus valve differential pressure) which support the above information.

90022296