



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

November 27, 1992

MEMORANDUM FOR: James M. Taylor  
Executive Director for Operations

FROM: Edward L. Jordan, Chairman  
Committee to Review Generic Requirements

SUBJECT: MINUTES OF CRGR MEETING NUMBER 227

The Committee to Review Generic Requirements (CRGR) met on Tuesday, August 25, 1992 from 8:00 a.m. to 6:00 p.m. A list of attendees at the meeting is attached (Enclosure 1). The following items were discussed at the meeting:

1. The CRGR was provided a briefing on proposed Supplement 1 to NRC Bulletin 92-01, "Failures of Thermo-Lag 330 Fire Barrier System to Perform Its Specified Fire Endurance Function", which the staff planned to issue as soon as possible as an immediately effective action (i.e., without full review by CRGR prior to issuance). The Committee did not object to the proposed action, but offered several comments for clarification of the proposed supplement. This matter is discussed in Enclosure 2.
2. The Committee considered a revised package for proposed Revision 4 to Regulatory Guide 1.28 (Quality Assurance Program Requirements) reviewed initially by CRGR at Meeting No. 220. The revised package reflected CRGR comments and recommendations from the earlier meeting. The Committee recommended in favor of issuing the revised package for comment, subject to only minor additional modifications (to be coordinated with the CRGR staff). This matter is discussed in Enclosure 3.
3. The CRGR discussed a proposed response to EDO questions relating to a proposal by the NRC Office of Regulatory Research to initiate rulemaking as the preferred means of resolving Generic Issue 23 (Raector Coolant Pump Seal Failures) and completing implementation of the station black-out rule, 10 CFR 50.63. This matter is discussed in Enclosure 4.
4. The CRGR began (but did not complete) its review of the proposed new Standard Technical Specifications (STS). The Committee agreed on the scope and mode of the review effort that would be required of CRGR in connection with the STS improvement activity; but no CRGR recommendations resulted from this meeting. This matter is discussed in Enclosure 5.

In accordance with the EDO's July 18, 1983 directive concerning "Feedback and Closure of CRGR Review", a written response is required from the cognizant office to report agreement or disagreement with the CRGR recommendations in these minutes. The response is to be forwarded to the CRGR Chairman and if there is disagreement with the CRGR recommendations, to the EDO for decision making.

10009 RETURN TO REGULATORY CENTRAL FILES

9212150226 921127  
PDR REVGP NRCGRGR  
MEETING227 PDR

DF03 10  
01/11/97  
CRGR

Questions concerning these meeting minutes should be referred to James H. Conran (492-9855).

Original Signed by:

E. L. Jordan

Edward L. Jordan, Chairman  
Committee to Review Generic  
Requirements

Enclosures:  
As stated

cc w/enc:  
Commission (5)  
SECY  
J. Lieberman  
P. Norry  
D. Williams  
W. Parler  
Regional Administrators  
C.E. Rossi  
B. Grimes  
W. Minners  
A. Thadani  
CRGR Members

Distribution:  
Central File w/o encl.  
PDR (NRC/CRGR) w/o encl.  
CRGR S/F  
CRGR C/F  
S. Treby  
M. Taylor  
J. Snizek  
D. Allison  
D. Ross  
J. Conran  
R. Emrit  
G. Holahan  
C. Grimes  
R. Baer  
O. Gormley

CRGR:AEOD  
JHConran:slm  
11/23/92

DD:AEOD  
DERuss  
11/24/92

C/CRGR:AEOD  
ELJordan  
11/25/92

DOCUMENT NAME: Minutes.228