

POOR ORIGINAL

Detroit
Edison

175 Second Avenue
Detroit, Michigan 48226
248 227-8000

January 7, 1980

EF2-47,2

Mr. James G. Keppler
Regional Director
U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Dear Mr. Keppler:

Subject: Interim Report of 10 CFR 50.55(e)
Item on Defective Westinghouse Switches


On December 7, 1979, Detroit Edison's Mr. H. A. Walker, EF2 Site Project Quality Assurance Engineer, telephoned Mr. F. J. Jablonski of NRC Region III to report on defective Westinghouse switches in distribution cabinets used to distribute power for plant instrumentation and control at the Fermi 2 Site.

These switches were manufactured by Westinghouse Electric Corporation and furnished to Detroit Edison by the Harlo Corporation. So far, the problem involves five switches which will not close properly. Four distribution cabinets are affected.

Detroit Edison is conducting a review to determine the extent of this problem, and arrangements are being made to meet with the supplier's representative to correct the situation. A final report will be submitted to you by May 7, 1980.

If you have any questions on this matter, please contact our EF2 Site Project Quality Assurance Engineer.

Sincerely,


W. J. Fahrner
Project Manager
Enrico Fermi 2

cc: Mr. John G. Davis
Acting Director
Office of Inspection and Enforcement
Division of Reactor Inspection Programs
U.S. Nuclear Regulatory Commission
Washington D.C. 20555

90018060

8001140443

Bola
5/10

S