

Duke Power Company
McGuire Nuclear Generation Department
12700 Rogers Ferry Road (MG01A)
Huntersville, NC 28078-8985

T. C. McMEEKIN
Vice President
(704)875-4800
(704)875-4809 FAX



DUKE POWER

December 10, 1992

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

Subject: McGuire Nuclear Station, Units 1 and 2
Docket Nos. 50-369 and 50-370
Proposed Technical Specification Amendment
Diesel Generator 18-Month Surveillance Mode
Restrictions (TS 4.8.1.1.2.e)

- Reference: 1) H.B. Tucker to NRC letter dated
February 10, 1989, same subject
- 2) T.C. McMeekin to NRC letter dated
April 30, 1992, same subject
- 3) T.C. McMeekin to NRC letter dated
November 16, 1992, same subject

Dear Sir;

A Technical Specification (TS) Amendment request to modify certain 18-month diesel generator Surveillance Requirements (SRs) for McGuire Nuclear Station was submitted by a letter dated February 10, 1989. The request was to allow for certain SRs currently required to be done during an outage, to be performed during power operation. Our basis for this request was to allow for greater scheduling flexibility with no impact on the safe operation of the unit. The initial TS Amendment request was supplemented by my letters dated April 30 and November 16, 1992.

Attached is TS page 3/4 8-6, which replaces the same page that was provided by my November 16, 1992 letter. This new page corrects an error within the same page that was previously submitted, in that it adds the phrase "during shutdown" to TS 4.8.1.1.2e.15).

9212170221 921210
PDR ADOCK 05000369
P PDR


Printed on recycled paper

1001

U. S. Nuclear Regulatory Commission
December 10, 1992
page 2

Should you have any questions concerning this amendment request, please contact Paul Guill at (704) 875-4002.

Very truly yours,



T. C. McMeekin

xc: Mr. S. D. Ebnetter
Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street, NW, Suite 2900
Atlanta Georgia 30323

Mr. P. K. Van Doorn
Senior NRC Resident Inspector, McGuire
McGuire Nuclear Station

Mr. T. A. Reed, Project Manager
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
One White Flint North, Mail Stop 9H3
Washington, D.C. 20555

U. S. Nuclear Regulatory Commission
December 10, 1992
page 3

bxc: with attachment

A. V. Carr (Legal)
E. M. Geddie
L. S. Charles
G. D. Gilbert
R. O. Sharpe
P. F. Guill
W. N. Matthews
D. T. Griffin
R. M. Roberts
R. L. Gill, Jr. (NS)
P. T. Vu
K. D. Thomas
\pfg067.nrc

P. R. Herran
R. B. Travis
B. H. Hamilton
J. N. Pope
R. B. White, jr
T. D. Curtis
R. J. Deese
W. M. Sample (NS)
D. W. Murdock (NS)
L. J. Kunka
NSRB (EC12A)
File: 801.01