


James A. FitzPatrick
Nuclear Power Plant
P.O. Box 41
Lycoming, New York 13093
315 342-3840



Harry P. Salmon, Jr.
Resident Manager

December 14, 1992
JAFP-92-0848

U.S. Nuclear Regulatory Commission
Mail Station P1-137
Washington, D.C. 20555


Attention: Document Control Desk
SUBJECT: OPERATING STATUS REPORT
Reference. DOCKET NO. 50-333

Dear Sir:

Enclosed please find the James A. FitzPatrick Nuclear Power Plant
Operating Status Report for the month of **November 1992**.

If there are any questions concerning this report, please contact
Russell Flagg at (315) 349-6590.

Very truly yours,


HARRY P. SALMON, JR.

HPS:RGF:yp *RSF*
Enclosure

CC: JAF Department Heads
White Plains Office
TS File
RMS, JAF

9212180007 921130
PDR ADOCK 05000333
R PDR

JE24

**NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
OPERATING DATA REPORT**

DOCKET NO.: 50-333
UNIT NAME: FITZPATRICK
DATE: DECEMBER 1992
COMPLETED BY: RUSS FLAGG
TELEPHONE: (315) 349-6590

OPERATING STATUS

1. Unit Name: FITZPATRICK
2. Reporting Period: 921101 - 921130
3. Licensed Thermal Power (MWT): 2436
4. Nameplate Rating (Gross MWE): 883
5. Design Electrical Rating (Net MWE): 816
6. Maximum Dependable Capacity (Gross MWE) 807
7. Maximum Dependable Capacity (Net MWE) 780

NOTES:

8. If changes occur in capacity ratings (Items 3-7) since last report, give reasons:

9. Power level to which restricted, if any (Net MWE): _____
10. Reasons for restrictions, if any: _____

	THIS MONTH	YR-TO-DATE	CUMULATIVE
11. Hours in Reporting Period:	722.0	6574.0	150600.0
12. Number of Hours Reactor was Critical:	0	0	104831.4
13. Reactor Reserve Shutdown Hours:	0	0	0
14. Hours Generator On-Line:	0	0	101731.2
15. Unit Reserve Shutdown Hours:	0	0	0
16. Gross Thermal Energy Generated (MWH):	0	0	223974910.0
17. Gross Electrical Energy Generated (MWH):	0	0	76322860.0
18. Net Electrical Energy Generated (MWH):	0	0	73269365.0
19. Unit Service Factor:	0	0	67.2
20. Unit Availability Factor:	0	0	67.2
21. Unit Capacity Factor (using MDC Net):	0	0	62.4
22. Unit Capacity Factor (using DER Net):	0	0	59.0
23. Unit Forced Outage Rate:	0	0	13.0

24. Shutdowns scheduled over next 6 months (type, date, and duration of each):
Refuel outage commenced January 11, 1992.
5. If shutdown at end of report period, estimated date of startup: December 21, 1992
26. Units in Test Status (prior to commercial operation):

	FORECAST	ACHIEVED
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
AVERAGE DAILY UNIT POWER LEVEL

REPORT MONTH: NOVEMBER 1992

DOCKET NO.: 50-333
UNIT NAME: FITZPATRICK
DATE: DECEMBER 1992
COMPLETED BY: RUSS FLAGG
TELEPHONE: (315)349-6590

DAY	AVERAGE DAILY POWER LEVEL	DAY	AVERAGE DAILY POWER LEVEL
1	0	17	0
2	0	18	0
3	0	19	0
4	0	20	0
5	0	21	0
6	0	22	0
7	0	23	0
8	0	24	0
9	0	25	0
10	0	26	0
11	0	27	0
12	0	28	0
13	0	29	0
14	0	30	0
15	0	31	
16	0		

SUMMARY: The FitzPatrick Plant remained shutdown for the entire reporting period.

NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
UNIT SHUTDOWNS REPORT

REPORT MONTH: NOVEMBER 1992

DOCKET NO.: 50-333
UNIT NAME: FITZPATRICK
DATE: DECEMBER 1992
COMPLETED BY: RUSS FLAGG
TELEPHONE: (315)349-6590

NO.	DATE	TYPE	D U H R O A U T R I S O N	R E A S O N	M E T H O D O F S H U T T I N G D O W N T H E R E A C T O R	L I C E N S E E E V E N T R E P O R T	S Y C S O T D E E M	C O M C P O D N E E N T	C A U S E A N D C O R R E C T I V E A C T I O N T O P R E V E N T R E C U R R E N C E
2	920601	S	720	C	1	N/A	N/A	N/A	S/D for Refue'ing Commenced 920110 (Cumulative hours 7791).

1
F: FORCED
S: SCHEDULED

2
REASON:
A. EQUIPMENT FAILURE (EXPLAIN)
B. MAINTENANCE OR TEST
C. REFUELING
D. REGULATORY RESTRICTION
E. OPERATOR TRAINING AND LICENSE EXAMINATION
F. ADMINISTRATIVE
G. OPERATIONAL ERROR (EXPLAIN)
H. OTHER (EXPLAIN)

3
METHOD:
1. MANUAL
2. MANUAL SCRAM
3. AUTOMATIC SCRAM
4. CONTINUED
5. REDUCED LOAD
9. OTHER

4
EXHIBIT G -INSTRUCTIONS
FOR PREPARATION OF DATA ENTRY
SHEETS FOR LICENSEE EVENT
REPORT (LER) FILE (NUREG-0161)

NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
NARRATIVE SUMMARY OF OPERATING EXPERIENCE

REPORT MONTH: NOVEMBER 1992

DOCKET NO.: 50-333
UNIT NAME: FITZPATRICK
DATE: DECEMBER 1992
COMPLETED BY: RUSS FLAGG
TELEPHONE: (315)349-6590

The FitzPatrick Plant remained shutdown for this entire reporting period.

The major work items during this reporting period were:

- Fire Protection System corrective maintenance/modifications
- Startup Surveillance Testing in Progress