




UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION I  
631 PARK AVENUE  
KING OF PRUSSIA, PENNSYLVANIA 19406

OCT 30 1987

Docket No. 50-336  
File RI-87-A-0113



Dear [REDACTED]

This letter supplements my October 16, 1987 letter to you and addresses your October 23, 1987 conversation with Monte Conner of my staff. We understand that you have a general concern about adequacy of electrical tagging. Based on your October 16, 1987 input, we now also understand that you have a concern about control of security lighting.

As my October 16, 1987 letter stated in regard to electrical tagging, the information received from you was not specific enough to be productively pursued as a separate inspection task. In your discussion with Monte Conner, no information was provided to change that evaluation.

In regard to security lighting, we identified a deficiency during an NRC inspection conducted from August 31 through September 4, 1987. This deficiency is documented in Section 10 of Combined Inspection Report 50-245/87-22; 50-336/87-20; 50-423/87-20 for the three Millstone units. That section documents an NRC security lighting survey conducted during the evening of September 2, 1987. Our survey revealed six areas below the 0.2 foot-candle minimum lighting requirement. This is an apparent Violation of NRC requirements. The licensee has taken action to correct this problem. Also, the NRC has scheduled a November 3, 1987 Enforcement Conference to discuss security lighting and other issues with the licensee. We will then consider whether additional NRC action is needed to assure continued adequacy of security lighting. Further, we will specifically verify the ongoing adequacy of licensee corrective actions during field inspections. Since we are already taking action on security lighting adequacy and that action appears to encompass your concern, no additional specific action based on your concern is planned.

For your information NRC Inspection reports for Millstone are available for public examination at the Local Public Docket Room at the Waterford Public Library.

Information in this record was deleted  
in accordance with the Freedom of Information  
Act, exemptions b7C  
FOIA- 91-162

N/6


OCT 30 1987

File RI-87-A-0113

2

If you have any additional information or questions, please do not hesitate to contact me. We will reconsider the need for further NRC action based on any additional information you provide.

Sincerely,



Ebe McCabe, Jr., Chief  
Reactor Projects Section 1B  
NRC Region I  
Telephone (215) 337-5231