

UNION ELECTRIC COMPANY

1901 GRATIOT STREET - ST. LOUIS

April 20, 1979

MAILING ADDRESS:
P. O. BOX 149
ST. LOUIS, MO. 63166

Samuel L. Pettijohn
Regional Licensing Section
License Management Branch
Division of Fuel Cycle and
Material Safety

Dear Mr. Pettijohn:

This letter refers to your inquiry dated April 4, 1979 in regards to the renewal of our byproduct material license No. 24-02020-03, Control No. 01521.

Reference Item No. 6. When maintenance is performed on equipment where personnel could be exposed to the radioactive source, the following precautions are taken: A) The source is placed in the shutter closed position; B) The shutter is padlocked closed with a Corbin Padlock, Key No. 4R16649C; C) The source is tagged "Out of Service" by the Operations Function Authority; D) The key for the padlock is secured in the Control Room and access is limited to the personnel that tagged the source "Out of Service".

Reference Item No. 7. The following organizations will perform the leakage testing of each sealed source:

A) Industrial Nucleonics Corporation
650 Ackerman Rd. P.O. Box 4887
Columbus, Ohio 43202
USNRC License 34-00255-03

B) Nuclear Research Corporation
1105 Industrial Highway
South Hampton, Pennsylvania 18966
USNRC License 37-02401-04G

Reference Item No. 10. The two organizations listed above for Item No. 7 will also perform the following services: A) Installation and Initial Radiation Survey of Gauges; B) Relocation; C) maintenance; D) Repair; E) Disposal.

8506140034 850531
REG3 LIC30
24-02020-03 PDR

R 30 1979

Reference Item No. 12. In the case of an accident involving the damage or loss of the gauge or devices the Operating Supervisor on duty will contact:


Mr. George R. Mills - Gen'l. Plt. Supt.
Labadie Power Plant
P.O. Box 67
Labadie, MO 63055
Telephone No. 314-621-3222 Ext. 58-201

Or
452 S. Gray
Webster Groves, MO 63119 (Home)
Telephone No. 314-961-7567

He will notify the local police, state personnel and the N.R.C.

Please advise if you require further clarification on these items.

Sincerely,



Mr. G. R. Murray
Union Electric Co.
P.O. Box 149
St. Louis, MO 63166

GAA/cmb
cc: File L-6