

TABLE I

SECONDARY CONTAINMENT LEAK RATE TEST DATA
 TEST DATE: JANUARY 5, 1980

TEST CONDITIONS

Wind Direction	~ East North East
Wind Velocity	~ 14 MPH
Barometric Pressure (outside Rx. Bldg.)	30.02" Hg
Outside Temperature	34° F.
Inside Temperature	74° F.

BASE READING (0 Flow)

Reactor Building Atmosphere ΔP ("H ₂ O)	N. + .28
	E. + .23
	W. + .18
	S. + .19

"A" SCTS PERFORMANCE

System Flow Rate -	3900 cfm
Reactor Bldg. Atmosphere ΔP ("H ₂ O)	N. - .23
	E. - .21
	W. - .02
	S. - .02
Secondary Containment Vacuum	- .34" H ₂ O

"S" SCTS PERFORMANCE

System Flow Rate	3950 cfm
Reactor Bldg. Atmosphere ΔP ("H ₂ O)	N. - .30
	E. - .22
	W. - .02
	S. - .02
Secondary Containment Vacuum	- .36" H ₂ O

8003110 601