



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

57

November 1, 1984

Docket No. 50-229

MEMORANDUM FOR: H. Denton R. Vollmer  
E. Case R. Bernero  
G. Edison H. Thompson  
D. Eisenhut B. Snyder  
F. Miraglia T. Speis  
G. Lainas [REDACTED]  
T. Novak S. Varga  
D. Crutchfield D. Vassallo  
J. Miller

THRU: John F. Stolz, Chief, Operating Reactors Branch #4, Division of Licensing *JS*  
FROM: Harley Silver, Project Manager  
Operating Reactors Branch #4, Division of Licensing  
SUBJECT: DAILY HIGHLIGHT - TMI-1 Steam Generator Hearing Initial Decision

The staff today received the ASLB Initial Decision on Steam Generator Repair dated October 31, 1984. The decision is favorable. It authorizes issuance of the requested license amendment recognizing the kinetic expansion repair techniques, subject to the conditions specified in the staff's SER, NUREG-1019, and Supplement 1 thereto. The decision adds two conditions which were discussed during the hearing, regarding (1) the installation and operability of a redundant secondary side radioactivity (leakage) monitor, and (2) considerations of eddy current examination after 180 days of operation at less than 50% power, should such operation occur.

The amendment package will be revised shortly and should be available for issuance by the end of November.

Harley Silver, Project Manager  
Operating Reactors Branch #4  
Division of Licensing