



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

September 1, 1983

- Mark
- ER
- file

Docket No. 50- 289

MEMORANDUM FOR: H. Denton
J. Carter
D. Eisenhut
R. Purple
T. Novak
G. Lainas
F. Miraglia

T. Speis
R. Vollmer
R. Mattson
H. Thompson
J. Snizek
~~W. H. H. H.~~

E. Case
S. Varga
D. Vassallo
J. Miller
D. Crutchfield
C. Heltemes

THRU: John F. Stolz, Chief, Operating Reactors Branch #4, *Sm for*
Division of Licensing

FROM: James A. VanVliet, Project Manager
Operating Reactors Branch #4, Division of Licensing

SUBJECT: DAILY HIGHLIGHT

TMI-1 STEAM GENERATOR LEAK RATES

Initial leak rate calculations for TMI-1 at normal operating pressure indicate an RCS leak rate of 0.1 - 0.2 gallons per minute. Primary to secondary leakage appears to be 0.80 - 0.85 gallons per hour. This is a small fraction of technical specification limits for primary to secondary leakage of 1 gallon per minute.

James A. VanVliet
James A. VanVliet
Operating Reactors Branch #4
Division of Licensing

CC:
JStolz
VanVliet
CIR#4 File

8506140312 850125
PDR FOIA
DETJEN84-897 PDR