

U. S. NUCLEAR REGULATORY COMMISSIONDOCKET NOS. 50-317 AND 50-318BALTIMORE GAS AND ELECTRIC COMPANYNOTICE OF EXTENSION FOR COMPLIANCE WITH  
REQUIREMENTS OF 10 CFR 50.48

By letter dated January 30, 1981, Baltimore Gas and Electric Company (the licensee) requested that the U. S. Nuclear Regulatory Commission (the Commission) grant an extension of time until June 1, 1981, for complying with the requirements of Section 50.48 of 10 CFR Part 50 (45 FR 76602, November 19, 1980).


This request is in connection with the licensee's need to postpone installation and testing of some items for the fire protection system at the Calvert Cliffs Unit Nos. 1 and 2 Nuclear Generating Station located in Calvert Cliffs, Maryland. Those items are as follows: (1) automatic fire suppression in cable spreading rooms, (2) emergency communications, (3) fire detection in safety-related areas, (4) fire hose coverage, (5) fire hazard analysis, (6) fire walls and barriers, (7) emergency lighting, and (8) reactor coolant pump lube oil collection.

Pursuant to 10 CFR 50.48(d), the Commission's Director of Nuclear Reactor Regulation has concluded that good cause has been shown and that such postponement will not adversely affect the health and safety of the public. Accordingly, the request has been granted to item number (1), (7), and (8), and the remaining items do not need an extension.

8108040929

For further details with respect to this action, see (1) the licensee's request dated January 30, 1981, and (2) the Director's letter to the licensee dated

FOR THE NUCLEAR REGULATORY COMMISSION

  
Edson G. Case, Deputy Director  
Office of Nuclear Reactor Regulation

Dated at Bethesda, Maryland  
this 13th day of February, 1981.