

December 28, 1992

Docket Nos. 50-369

Mr. T. C. McMeekin
Vice President, McGuire Site
Duke Power Company
12700 Hagers Ferry Road
Huntersville, North Carolina 28078-8985

Dear Mr. McMeekin:

SUBJECT: SAFETY EVALUATION ON ISI RELIEF REQUEST NO. 92-02
(TAC NO. M84346)

By letter dated August 19, 1992, Duke Power Company (DPC) submitted an ISI Relief Request 92-02 for McGuire Nuclear Station Unit 1. Relief Request 92-02 requests extension of the first ten-year ISI interval to coincide with the start of the end-of-cycle 8 refueling outage for McGuire Unit 1. The staff previously approved a similar request (RR 90-02); however, subsequent unit outages necessitated the need for the current request.

The enclosed Safety Evaluation provides the results of the staff's review of the requested relief. The relief is granted until the end of the McGuire Unit 1 cycle 8 refueling outage. If the licensee determines that continued relief is required, a revised relief request will be required.

Accordingly, relief is granted as requested, pursuant to 10 CFR 50.55a(g)(6)(i). This relief is authorized by law and will not endanger life or property or the common defense and security, and is otherwise in the public interest, given due consideration to the burden that could result if the requirements were imposed on your facility.

This concludes our review activities of Relief Request 92-02.

Sincerely,

/s/

David B. Matthews, Director
Project Directorate II-3
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

Enclosure:
Safety Evaluation

cc w/enclosure:
See next page
*SEE PREVIOUS CONCURRENCE

LA:PDII-3
LBerry

12/28/92

PL:PDII-3
TReed:cw
12/28/92

DISTRIBUTION:
SEE NEXT PAGE

OGC*

12/21/92

D:PDII-3
DMatthews
12/28/92

310000

9301050137 921228
PDR ADOCK 05000369
P PDR

DF01
111



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555
December 28, 1992

Docket No. 50-369

Mr. T. C. McMeekin
Vice President, McGuire Site
Duke Power Company
12700 Hagers Ferry Road
Huntersville, North Carolina 28078-8985

Dear Mr. McMeekin:

SUBJECT: SAFETY EVALUATION ON ISI RELIEF REQUEST NO. 92-02
(TAC NO. M84346)

By letter dated August 19, 1992, Duke Power Company (DPC) submitted an ISI Relief Request 92-02 for McGuire Nuclear Station Unit 1. Relief Request 92-02 requests extension of the first ten-year ISI interval to coincide with the start of the end-of-cycle 8 refueling outage for McGuire Unit 1. The staff previously approved a similar request (RR 90-02); however, subsequent unit outages necessitated the need for the current request.

The enclosed Safety Evaluation provides the results of the staff's review of the requested relief. The relief is granted until the end of the McGuire Unit 1 cycle 8 refueling outage. If the licensee determines that continued relief is required, a revised relief request will be required.

Accordingly, relief is granted as requested, pursuant to 10 CFR 50.55a(g)(6)(i). This relief is authorized by law and will not endanger life or property or the common defense and security, and is otherwise in the public interest, given due consideration to the burden that could result if the requirements were imposed on your facility.

This concludes our review activities of Relief Request 92-02.

Sincerely,

A handwritten signature in dark ink, appearing to read "David B. Matthews", is written over the typed name.

David B. Matthews, Director
Project Directorate II-3
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

Enclosure:
Safety Evaluation

cc w/enclosure:
See next page

Mr. T. C. McMeekin
Duke Power Company

McGuire Nuclear Station

cc:

Mr. A. V. Carr, Esquire
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242-0001

County Manager of Mecklenberg County
720 East Fourth Street
Charlotte, North Carolina 28202

Mr. R. O. Sharpe
Compliance
Duke Power Company
McGuire Nuclear Site
12700 Hagers Ferry Road
Huntersville, NC 28078-8985

J. Michael McGarry, III, Esquire
Winston and Strawn
1400 L Street, NW.
Washington, DC 20005

Senior Resident Inspector
c/o U. S. Nuclear Regulatory
Commission
12700 Hagers Ferry Road
Huntersville, North Carolina 28078

Mr. T. Richard Puryear
Nuclear Technical Services
Manager
Carolinas District
Westinghouse Electric Corporation
P. O. Box 32817
Charlotte, North Carolina 28232

Dr. John M. Barry
Mecklenburg County
Department of Environmental
Protection
700 N. Tryon Street
Charlotte, North Carolina 28202

Mr. Dayne H. Brown, Director
Department of Environmental,
Health and Natural Resources
Division of Radiation Protection
P. O. Box 27687
Raleigh, North Carolina 27611-7687

Mr. Alan F. Herdt, Chief
Project Branch #3
U. S. Nuclear Regulatory Commission
101 Marietta Street, NW. Suite 2900
Atlanta, Georgia 30323

Ms. Karen E. Long
Assistant Attorney General
North Carolina Department of
Justice
P. O. Box 629
Raleigh, North Carolina 27602

Mr. R. L. Gill, Jr.
Licensing
Duke Power Company
P. O. Box 1006
Charlotte, North Carolina 28201-1006

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, NW. Suite 2900
Atlanta, Georgia 30323

Letter Dated: December 28, 1992

Distribution:

Docket File

NRC & Local PDRs

PDII-3 R/F

McGuire R/F

T. Murley/F. Miraglia

J. Partlow

C. Rossi

J. Lieberman

S. Varga

G. Lainas

D. Matthews

L. Berry

T. Reed

OGC

E. Jordan

G. Hill (8)

ACRS (10)

PA

OC/LFMB

L. Plisco, 17G20

E. Merschoff, RII