

APPENDIX A

NOTICE OF VIOLATION

Louisiana Power and Light Company  
Waterford Steam Electric Station, Unit 3

Docket: 50-382  
License: NPF-38

Based on the results of an NRC inspection conducted during the period of April 29-May 3, 1985, and in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C), 49 FR 8583, dated March 8, 1984, the following violation was identified:

Failure to Establish Sampling Procedure

Technical Specification 6.8.1.a requires that "written procedures shall be established, implemented, and maintained covering the activities . . . recommended in Appendix A of Regulatory Guide 1.33, Revision 2, February 1978. . . ." Paragraph 7 of Appendix A addresses gaseous effluent sampling procedures. Chemistry department procedure CE-3-305, "Sampling of Ventilation and Gaseous Waste Management Systems for Radioactive Effluents," describes the procedure for sampling of waste gas decay tanks.

Contrary to the above, on April 30, 1985, the NRC inspector observed sampling of waste gas decay tank "B" which was collected from the pressure indicator gauge associated with that waste gas decay tank, without the use of an approved procedure, using a method not described in procedure CE-3-305.

This is a Severity Level V Violation. (Supplement I) (382/8517-02)

Pursuant to the provisions of 10 CFR 2.210, Louisiana Power and Light Company is hereby required to submit to this office, within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

Dated: JUN 13 1985

8506180334 850613  
PDR ADOCK 05000382  
3 PDR