



SACRAMENTO MUNICIPAL UTILITY DISTRICT 6201 S Street, P.O. Box 15830, Sacramento, CA 95813; (916) 452-3211
AN ELECTRIC SYSTEM SERVING THE HEART OF CALIFORNIA

RJR 85-148

May 31, 1985

DIRECTOR OF NUCLEAR REACTOR REGULATION
ATTENTION HUGH L THOMPSON JR. DIRECTOR
DIVISION OF LICENSING
U S NUCLEAR REGULATORY COMMISSION
WASHINGTON D C 20555

DOCKET 50-312
RANCHO SECO NUCLEAR GENERATING STATION
UNIT NO. 1
GENERIC LETTER 83-28, REACTOR TRIP SYSTEM RELIABILITY (AUTOMATIC ACTUATION
OF THE SHUNT TRIP ATTACHMENT)

Your letter dated August 10, 1984 completed your pre-implementation review of the requirements of Item 4.3 of Generic Letter 83-28. You also requested verification of the seismic and environmental qualification of the shunt trip devices. The District has completed this review and has verified that the shunt trip devices are seismically and environmentally qualified.

If you have any questions about this analysis please call Robert Roehler of my staff at (209) 333-2935, ext. 4905.

R. J. Rodriguez
Assistant General Manager,
Nuclear

8506100420 850531
PDR ADDCK 05000312
PDR

A055
1/0