

JUN 04 1985

Dockets Nos. 50-321
and 50-366

Mr. J. T. Beckham, Jr.
Vice President - Nuclear Generation
Georgia Power Company
P. O. Box 4545
Atlanta, Georgia 30302

DISTRIBUTION

Docket File

NRC PDR
L PDR
ORB#4 Rdg
HThompson
OELD
EJordan

BGrimes
JPartlow
ACRS-10
RIngram
GRivenbark
Gray File

Dear Mr. Beckham:

We have completed our review of your August 12, 1983, request for relief for Hatch Units 1 and 2 from the American Society of Mechanical Engineers Section XI Code requirements for inservice testing of pumps and valves. This August 12, 1983, request superseded your earlier January 27, 1981, request for relief. As indicated in the enclosed Safety Evaluations (SEs), we have concluded that certain of the relief requests should be granted and others conditionally granted. The enclosed SEs provide the details of our review, and Attachment 1 to the SEs provides a summary tabulation of our conclusions concerning each request.

We have determined pursuant to 10 CFR Part 50.55a(g)(6)(i), that the granting of this relief is authorized by law and will not endanger life or property or the common defense and security and is otherwise in the public interest. In making this determination, we have given due consideration to the burden that could result if these requirements were imposed on your facility.

In our evaluation of your program, we identified possible deficiencies in the scope of the program. These are summarized in Section C.2 of the SEs. It is our understanding, based on discussion with and oral commitments from your staff, that you will examine the functions of the systems and individual valves identified in Section C.2, considering our position as described in Section A of the SEs, and will either include them in your revised IST program to be submitted in June 1985, or provide justification for their omission.

Sincerely,

John F. Stolz
JOHN F. STOLZ

John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

Enclosures:

1. Safety Evaluation - Unit 1
2. Safety Evaluation - Unit 2

cc w/enclosures:

See next page

*See previous white for concurrences:

ORB#4:DL	ORB#4:DL	ORB#3:DL
RIngram	GRivenbark;cr	PTam*
5/20/85	5/20/85	5/10/85

ORB#4:DL
JStolz *
5/10/85

OELD
Stolz
5/21/85

8506180536 850604
PDR ADOCK 05000321
PDR

Dockets Nos. 50-321
and 50-366

Mr. J. T. Beckham, Jr.
Vice President - Nuclear Generation
Georgia Power Company
P. O. Box 4545
Atlanta, Georgia 30302

DISTRIBUTION

Docket File
NRC PDR
L PDR
ORB#4 Rdg
HThompson
OELD
EJordan

BGrimes
JPartlow
ACRS-10
RIngram
GRivenbark
Gray File

Dear Mr. Beckham:

We have completed our review of your August 12, 1983, request for relief for Hatch Units 1 and 2 from the American Society of Mechanical Engineers Section XI Code requirements for inservice testing of pumps and valves. This August 12, 1983, request superseded your earlier January 27, 1981, request for relief. As indicated in the enclosed Safety Evaluations (SEs), we have concluded that certain of the relief requests should be granted, others conditionally granted and one for each unit denied. The enclosed SEs provide the details of our review, and Attachment 1 to the SEs provides a summary tabulation of our conclusions concerning each request.

We have determined pursuant to 10 CFR Part 50.55a(g)(6)(i), that the granting of this relief is authorized by law and will not endanger life or property or the common defense and security and is otherwise in the public interest. In making this determination, we have given due consideration to the burden that could result if these requirements were imposed on your facility.

In our evaluation of your program, we identified possible deficiencies in the scope of the program. These are summarized in Section C.2 of the SEs. It is our understanding, based on discussion with and oral commitments from your staff, that you will examine the functions of the systems and individual valves identified in Section C.2, considering our position as described in Section A of the SEs, and will either include them in your revised IST program to be submitted in June 1985, or provide justification for their omission.

Sincerely,

John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

Enclosures:

1. Safety Evaluation - Unit 1
2. Safety Evaluation - Unit 2

cc w/enclosures:
See next page

ORB#4:DL
RIngram
5/9/85

ORB#4:DL
GRivenbark;cr
5/9/85

ORB#3:DL
PTam
5/10/85

ORB#4:DL
JStolz
5/10/85

AD:DE
JKnight
5/11/85

OELD
5/15/85

Hatch 1/2
Georgia Power Company

50-321 and 50-366

cc w/enclosure(s):

G. F. Trowbridge, Esq.
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Regional Radiation Representative
EPA Region IV
345 Courtland Street, N. E.
Atlanta, Georgia 30308

Ruble A. Thomas
Vice President
P. O. Box 2625
Southern Company Services, Inc.
Birmingham, Alabama 35202

Resident Inspector
U. S. Nuclear Regulatory Commission
Route 1, P. O. Box 279
Baxley, Georgia 31513

Louis B. Long
Southern Company Services, Inc.
P. O. Box 2625
Birmingham, Alabama 35202

Dr. J. Nelson Grace, Regional
Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 2900
Atlanta, Georgia 30303

Chairman
Appling County Commissioners
County Courthouse
Baxley, Georgia 31513

Charles H. Badger
Office of Planning and Budget
Room 610
270 Washington Street, S. W.
Atlanta, Georgia 30334

Mr. L. T. Gucwa
Georgia Power Company
Engineering Department
P. O. Box 4545
Atlanta, Georgia 30302

J. Leonard Ledbetter, Commissioner
Department of Natural Resources
270 Washington Street, N. W.
Atlanta, Georgia 30334

Mr. H. C. Nix, Jr. General Manager
Edwin I. Hatch Nuclear Plant
Georgia Power Company
P. O. Box 442
Baxley, Georgia 31513