



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SACRAMENTO MUNICIPAL UTILITY DISTRICT

DOCKET NO. 50-312

RANCHO SECO NUCLEAR GENERATING STATION

AMENDMENT TO FACILITY OPERATING LICENSE


Amendment No. 67  
License No. DPR-54

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Sacramento Municipal Utility District (the licensee) dated August 22, 1984, as supplemented by letters dated December 21, 1984, February 22, 1985, and March 14, 1985, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, Facility Operating License No. DPR-54 is hereby amended by adding Paragraph 2.C.(12) to read as follows:
  - (a) The schedule for completion of Item III.D.3.4 under Section III of the Commission's March 14, 1983, as revised November 10, 1983, Order Confirming Licensee Commitments on Post-TMI Related Issues, is revised to show the licensee's completion date as startup from the refueling outage currently estimated to begin in September 1986.
  - (b) Prior to startup from the refueling outage which started in March 1985, the licensee will:
    1. complete the installation of a redundant, two-train Heating Ventilating and Air Conditioning System and, on loss of offsite

power, load the B train automatically onto the existing diesel generators; and

2. change procedures to reflect the interim installation, and instruct the operators on the modified procedures.
3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

  
John F. Stolz, Chief  
Operating Reactors Branch #4  
Division of Licensing

Date of Issuance: May 30, 1985