



Commonwealth Edison

72 West Adams Street, Chicago, Illinois

Address Reply to: Post Office Box 767
Chicago, Illinois 60690

March 30, 1981

Mr. James G. Keppler
Regional Director
Office Of Inspection And Enforcement
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Subject: DRESDEN STATION 1980 LIQUID DOSE TABLES

Dear Mr. Keppler:

The attached tables of maximum doses resulting from liquid effluents are submitted, as an attachment to this report. This data was not available at the time the report was printed.

Sincerely yours,

J.C. Golden
Supervisor
Radioecology/Emergency Planning

JCG/vls

8104290 110

DRESDEN UNIT TWO AND THREE

MAXIMUM DOSES (MREM) RESULTING FROM LIQUID EFFLUENTS Δ

PERIOD OF RELEASE - 1/ 1/80 TO 12/31/80 CALCULATED 03/27/81 *

DOSE TYPE	PERIOD	1ST PREV QUARTER	2ND PREV QUARTER	3RD PREV QUARTER	4TH PREV QUARTER	ANNUAL
TOTAL	0.0	0.0	0.27E-03	0.13E-02	0.57E-04	0.17E-02
BODY						
INTERNAL	0.0	0	0.11E-02	0.18E-02	0.31E-02	0.39E-02
ORGAN						
		BONE	THYROID	LIVER	GI-LLI	GI-LLI
		LIVER				
		THYROID				
		KIDNEY				
		LUNG				
		GI-LLI				

* THIS IS A REPORT BASED ON FOUR PREVIOUS QUARTERS

COMPLIANCE STATUS

TYPE	10 CFR 50 APP. I QUARTERLY OBJECTIVE	% OF APP. I	10 CFR 50 APP. I YEARLY OBJECTIVES	% OF APP. I
TOTAL	0.15E 01 (MREM)	0.0	0.30E 01 (MREM)	0.56E-01
BODY				
CRITICAL	0.50E 01 (MREM)	0.0	0.10E 02 (MREM)	0.39E-01
ORGAN				
		BONE		GI-LLI
		LIVER		
		THYROID		
		KIDNEY		
		LUNG		
		GI-LLI		

Δ No Liquid releases from Dresden Unit #1.

POOR ORIGINAL