

REGULATORY DOCKET FILE COPY

Docket No. 50-309

Mr. Robert H. Groce
Senior Engineer - Licensing
Maine Yankee Atomic Power Company
1671 Worcester Road
Framingham, Massachusetts 01701

Dear Mr. Groce:

DISTRIBUTION:

Docket File
NRC PDR
L PDR
NSIC
TERA
ORB#3 Rdg
DEisenhut
JWetmore
RAClark
GRequa
PMKreutzer (3)
I&E (3)
OELD
GDeegan (4)
ACRS (10)
Gray File (+4)

MAY 05 1981

This confirms our telephone Authorization given today, May 5, 1981, for a change in Technical Specifications for the Maine Yankee Atomic Power Station as requested in your telecopy of May 5, 1981. Facility Operating License No. DPR-36 is amended on this date by making the following Technical Specification changes:

Add to paragraph 3.19 b) 2. the following exception:

Exception: Breakers for loop isolation valves RC-M-21 and RC-M-22 need not be opened and padlocked and the thermal overload links for these valves need not be physically removed during the period between May 5, 1981 and May 9, 1981.

Copies of the license amendment, our evaluation and our Federal Register Notice for this technical specification change will be sent to you when completed.

Sincerely,

Original signed by:

Thomas M. Novak, Assistant Director
for Operating Reactors
Division of Licensing

cc: See next page

8105150448

THIS DOCUMENT CONTAINS
POOR QUALITY PAGES



OFFICE	ORB#3:DL	ORB#3:DL	ORB#3:DL	AD:OR:DL			
SURNAME	PMKreutzer	GRequa/pn	RAClark	TMNovak			
DATE	/81	5/5/81	5/5/81	5/5/81			