

BIW CABLE SYSTEMS, INC.

January 13, 1984

United States Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

Attention: Uldis Potapovs, Chief
Vendor Program Branch

Dear Mr. Potapovs:


QUALITY ASSURANCE PROGRAM INSPECTION
DOCKET NO. 99900283/83-02

As requested in your letter of December 16, 1983, the enclosed action has been taken to correct the nonconformance reported by Mr. L. B. Parker during the inspection on August 29 - September 2, 1983.

I trust that the action taken complies with your request and that the nonconformance can be considered as resolved.

Very truly yours,

BIW CABLE SYSTEMS, INC.


Eli Manchester, Jr.
President

md

Attachment

8506190292 850327
PDR FOIA
CURRAN84-863 PDR

C100



Nonconformance

A qualification file, including a test plan, test procedure and supporting data, has been established for all cables submitted for qualification subsequent to the N.R.C. visit of August 29 - September 2, 1983. This qualification file also pertains to those cables manufactured as part of a research and development program with the goal of possible nuclear applications.