

NOV 13 1992

FILE COPY

Docket Nos. 50-325, 50-324
License Nos. DPR-71, DPR-62

Carolina Power and Light Company
ATTN: Mr. R. A. Watson
Senior Vice President
Nuclear Generation
P. O. Box 1551
Raleigh, NC 27602

Gentlemen:

SUBJECT: ENFORCEMENT CONFERENCE - BRUNSWICK

This confirms the telephone conversation between Mr. R. B. Richey of your staff and Mr. H. O. Christensen of this office on November 5, 1992, concerning an Enforcement Conference to be conducted at the Region II Office, Atlanta, Georgia on November 24, 1992, at 10:00 a.m. We requested this meeting to discuss the inadequately controlled Unit 1 reactor water level draining evolution which resulted in the inadvertent low level isolation of shutdown cooling on October 2, 1992. A proposed meeting agenda is enclosed.

Should you have any questions regarding these arrangements, we will be pleased to discuss them.

Sincerely,
Original signed by:
Jon R. Johnson/for

Ellis W. Merschoff, Director
Division of Reactor Projects

Enclosure:
Proposed Meeting Agenda

cc w/encl:
R. E. Morgan
Interim Manager
Brunswick Nuclear Project
P. O. Box 10429
Southport, NC 28461

(cc w/encl cont'd - See page 2)

9301070275 921113
PDR ADOCK 05000325
S PDR

IE01

NOV 13 1992

Carolina Power and Light Company

2

(cc w/encl cont'd)
H. Ray Starling
Vice President - Legal Department
Carolina Power and Light Co.
P. O. Box 1551
Raleigh, NC 27602

Kelly Holden
Board of Commissioners
P. O. Box 249
Colivia, NC 28422

Chrys Baggett
State Clearinghouse
Budget and Management
116 West Jones Street
Raleigh, NC 27603

Dayne H. Brown, Director
Division of Radiation Protection
N. C. Department of Environment,
Health & Natural Resources
P. O. Box 27687
Raleigh, NC 27611-7687

H. A. Cole
Special Deputy Attorney General
State of North Carolina
P. O. Box 629
Raleigh, NC 27602

Robert P. Gruber
Executive Director
Public Staff - NCUC
P. O. Box 29520
Raleigh, NC 27626-0520

Ms. Gayle B. Nichols
Staff Counsel
SC Public Service Commission
P. O. Box 11649
Columbia, SC 29211

bcc w/encl: (See page 3)

NOV 13 1992

Carolina Power and Light Company

3

bcc w/encl:

Document Control Desk

H. Christensen, RII

R. Lo, NRR

NRC Resident Inspector

U.S. Nuclear Regulatory Commission

Star Route 1, Box 208

Southport, NC 28461

RII:DRP

RCarroll:tj

11/12/92

RII:DRP

HChristensen

11/12/92

RII:DRP

DVerrelli

11/12/92

RII:DRS

AGibson

11/ /92

RII:ELCS

GJenkins

11/12/92

RII:DRP

JJohnson

11/13/92

ENCLOSURE

Proposed Meeting Agenda

November 23, 1992

- | | |
|---|--------------|
| I. Opening Remarks | S. D. Ebner |
| II. Discussion Of The October 2, 1992,
Unit 1 Reactor Water Level Draining
Event With Respect To: | R. E. Morgan |
| a. Inadequate Command, Control and Communications: | |
| <ul style="list-style-type: none">- Inattentiveness and/or unawareness of draining evolution by control room operators.- Existence/tolerance of control room distractions (i.e., reading of non-operational material, excessive administrative duties, etc.). | |
| b. Inadequate Management/Programmatic Controls: | |
| <ul style="list-style-type: none">- Scheduling/providing clearance for the digital feedwater modification without adequately communicating, or compensating for, the disablement of the audible high/low level annunciator.- Scheduled/planned use of RHR Loop B as a primary shutdown cooling method, despite a known valve deficiency.- Corrective actions taken on October 1, 1992, to preclude excessive vessel draining. | |
| III. Closing Remarks | S. D. Ebner |