

50-354

Thomas J. Martin
Vice President
Engineering and Construction

Public Service Electric and Gas Company 80 Park Plaza Newark, N.J. 07101 201/430-8316

July 17, 1985

Dr. Thomas E. Murley, Administrator
U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Dr. Murley:

NRC INSPECTION REPORT #85-17
NOTICE OF VIOLATION
HOPE CREEK GENERATING STATION

Your letter dated June 18, 1985, transmitted the above referenced Inspection Report which contained a Notice of Violation citing one (1) item of noncompliance concerning past due maintenance activities. The following response is provided in accordance with the Notice of Violation.

As of April 18, 1985, the Inspector identified numerous safety-related "Q" preventive maintenance activities that had not been performed in accordance with the schedule for systems and equipment turned over from Bechtel Construction to PSE&G startup/operations and maintenance was past due for these activities.

Corrective Steps Taken and Results Achieved

On April 18, 1985, a meeting was held to clarify responsibilities for the PSE&G-Bechtel preventive maintenance interface. Results of the meeting include: assignment of counterparts, weekly exchange of information, and a weekly report to station management. Also, two (2) station personnel have been dedicated to the timely review of Maintenance Action Cards upon receipt from Bechtel. To date, all overdue maintenance activities have been performed.

8507310038 850717
PDR ADCK 05000354
G PDR

11
1E 01

Corrective Steps Taken to Preclude Recurrence

Station Procedure MD-AP-ZZ-010(Q), entitled "Preventive Maintenance" has been revised to provide for Maintenance Action Card review for applicability and clarity. This procedure has been reviewed by Quality Assurance and will require SORC review prior to issuance.

The Date of Full Compliance

Procedure MD-AP-ZZ-010(Q), Revision 1, will be issued by August 9, 1985.

Very truly yours,

A handwritten signature in cursive script, appearing to read "T. J. Martin", is written over the typed name.

C Office of Inspection and Enforcement
Division of Reactor Construction Inspection
Washington, D. C. 20555

NRC Resident Inspector
P. O. Box 241
Hancocks Bridge, NJ 08038