

JUN 07 1985

Dockets Nos. 50-321
and 50-366

Mr. J. T. Beckham, Jr.
Vice President - Nuclear Generation
Georgia Power Company
P. O. Box 4545
Atlanta, Georgia 30302

DISTRIBUTION

Docket File

NRC PDR
L PDR
ORB#4 Rdg
HThompson
OELD
EJordan

JPartlow
ACRS-10
RIngram
GRivenbark
Gray File
BGrimes

Dear Mr. Beckham:

We have reviewed your November 7, 1983 responses to Item 1.1, Post-Trip Review (Program Description and Procedure) of Generic Letter 83-28 concerning required actions based on generic implications of Salem anticipated transient without scram (ATWS) events.

We find that your response does not meet the guidelines developed for post-trip review in the following areas:

1. The criteria for determining the acceptability of the restart.
2. The responsibilities and authorities of the responsible personnel performing the Post-Trip Review.
3. The method and criteria for comparing the event with expected plant performance.
4. The criteria for determining the need for independent assessment of the event following a trip.
5. A systematic safety assessment program to assess unscheduled reactor trip.

These deficiencies are discussed in greater detail in Section III of the enclosed SER.

Acceptable responses to the noted deficiencies are required before we can complete our review of your Post-Trip Review Program and Procedures. We request that you submit the additional information needed to correct these deficiencies within 60 days of receipt of this letter.

8506200015 850607
PDR ADOCK 05000321
P PDR

Mr. Beckham

-2-

This request for additional information was approved by the Office of Management and Budget under clearance number 3150-0011 which expires June 30, 1985. Comments on burden and duplication may be directed to the Office of Management and Budget, Reports Management Room 3208, New Executive Office Building, Washington, D. C. 20503.

Sincerely,

"ORIGINAL SIGNED BY
JOHN F. STOLZ"

John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

Enclosure:
Safety Evaluation Report

cc w/enclosure:
See next page

ORB#4:DL
GRivenbark;cr
6/6/85

ORB#4:DL
JStolz
6/7/85

Mr. J. T. Beckham, Jr.
Georgia Power Company

Edwin I. Hatch Nuclear Plant,
Units Nos. 1 and 2

cc:
G. F. Trowbridge, Esq.
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D.C. 20036

Mr. L. T. Gucwa
Engineering Department
Georgia Power Company
P. O. Box 4545
Atlanta, Georgia 30302

Mr. H. C. Nix, Jr., General Manager
Edwin I. Hatch Nuclear Plant
Georgia Power Company
P. O. Box 442
Baxley, Georgia 31513

Mr. Louis B. Long
Southern Company Services, Inc.
P. O. Box 2625
Birmingham, Alabama 35201

Resident Inspector
U.S. Nuclear Regulatory Commission
Route 1, P. O. Box 279
Baxley, Georgia 31513

Dr. J. Nelson Grace, Regional
Administrator
U.S. Nuclear Regulatory Commission,
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Mr. Charles H. Badger
Office of Planning and Budget
Room 610
270 Washington Street, S.W.
Atlanta, Georgia 30334

Mr. J. Leonard Ledbetter, Commissioner
Department of Natural Resources
270 Washington Street, N.W.
Atlanta, Georgia 30334

Chairman
Appling County Commissioners
County Courthouse
Baxley, Georgia 31513