



Metropolitan Edison Company
Post Office Box 480
Middletown, Pennsylvania 17057
717 ~~948-8000~~ 948-8000

Writer's Direct Dial Number

May 11, 1981
LL2-81-0130

Office of Inspection and Enforcement
Attn: Boyce H. Grier, Director
Region I
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Sir:

Three Mile Island Nuclear Station, Unit II (TMI-II)
Operating License No. DPR-73
Docket No. 50-320
Licensee Event Report No. 81-13/1P

This letter is to confirm the conversation between Mr. J. J. Chwastyk, Unit II Manager of Operations and Mr. R. J. Conte, Senior Resident Inspector, TMI-II, TMI Program Office at 1445 hours on May 8, 1981.

A condition considered reportable under Technical Specification 6.9.1.8(b) was entered at 1445 hours on May 8, 1981.

At this time, it was determined that incore thermocouple L-11 had failed, this leaves 42 operable thermocouples. This condition is considered reportable in accordance with Technical Specification 3.3.3.6, hence a prompt report is submitted.

Further details will be included in the follow-up report.

Sincerely,

G. K. Hovey
Director, TMI-2

GKH/MRH/la

cc: L. H. Barrett, Deputy Program Director

POOR ORIGINAL

8106040 274
S

1002
5/11

Received TMI-20
5/11/81 35

CONTROL BLOCK:

--	--	--	--	--	--

 (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

05/01/2016 04:47