

JUN 7 1985

Docket No. 50-458

Distribution
Docket File
NRC PDR
Local PDR
PRC System
NSIC
LB#2 Reading
Licensing Assistant
Project Manager, Stephen Stern
JPartlow
BGrimes
EJordan
J. Bongarro, D. H. F. S.
OELD, Dewey
ACRS (16)

Mr. William J. Cahill, Jr.
Senior Vice President
River Bend Nuclear Group
Gulf States Utilities Company
Post Office Box 2951
Beaumont, Texas 77704
ATTN: Mr. J. E. Booker

Dear Mr. Cahill:

Subject: Request for Additional Information - Emergency Operating Procedures

As a part of the NRC staff's review of your application for an operating license for River Bend Station, the staff has determined the need for additional information in the area of Emergency Operating Procedures (Confirmatory Item 60). The request for information is included in the enclosure. The question refers to a submittal from J. E. Booker of GSU to H. R. Denton of NRC dated May 15, 1985 (RBG-21,017).

Please inform NRC Project Manager, Stephen Stern, of your schedule for response and for clarification or further discussion on this topic.

Sincerely,

Original signed by

Walter Butler, Chief
Licensing Branch No. 2
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

8506200103 850607
PDR ADOCK 05000458
F PDR

OFFICE	LB#2/DL	LB#2/DL				
SURNAME	SStern:mk	WButler				
DATE	06/6/85	06/6/85				



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

JUN 7 1985

Docket No. 50-458

Mr. William J. Cahill, Jr.
Senior Vice President
River Bend Nuclear Group
Gulf States Utilities Company
Post Office Box 2951
Beaumont, Texas 77704
ATTN: Mr. J. E. Booker

Dear Mr. Cahill:

Subject: Request for Additional Information - Emergency Operating
Procedures

As a part of the NRC staff's review of your application for an operating license for River Bend Station, the staff has determined the need for additional information in the area of Emergency Operating Procedures (Confirmatory Item 60). The request for information is included in the enclosure. The question refers to a submittal from J. E. Booker of GSU to H. R. Denton of NRC dated May 15, 1985 (RBG-21,017).

Please inform NRC Project Manager, Stephen Stern, of your schedule for response and for clarification or further discussion on this topic.

Sincerely,

A handwritten signature in cursive script, reading "Walter R. Butler".

Walter Butler, Chief
Licensing Branch No. 2
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

Mr. William J. Cahill, Jr.
Gulf States Utilities Company

River Bend Nuclear Plant

cc: Troy B. Conner, Jr., Esq.
Conner and Wetterhahn
1747 Pennsylvania Avenue, N. W.
Washington, D.C. 20006

Ms. Linda B. Watkins/Mr. Steven Irving
Attorney at Law
355 Napoleon Street
Baton Rouge, Louisiana 70802

Mr. William J. Reed, Jr.
Director - Nuclear Licensing
Gulf States Utilities Company
Post Office Box 2951
Beaumont, Texas 77704

Mr. David Zaloudek
Nuclear Energy Division
Louisiana Department of
Environmental Quality
Post Office Box 14690
Baton Rouge, Louisiana 70898

H. Anne Plettinger
3456 Villa Rose Dr.
Baton Rouge, Louisiana 70806

Richard M. Troy, Jr., Esq.
Assistant Attorney General in Charge
State of Louisiana Department of Justice
234 Loyola Avenue
New Orleans, Louisiana, 70112

Mr. J. David McNeill, III
William G. Davis, Esq.
Department of Justice
Attorney General's Office
7434 Perkins Road
Baton Rouge, Louisiana 70806

Dwight L. Chamberlain
Resident Inspector
Post Office Box 1061
St. Francisville, Louisiana 70775

Gretchen K. Rothschild
Louisianians for Safe Energy, Inc.
1655 Clermont Avenue
Baton Rouge, Louisiana 70775

James W. Pierce, Jr., Esq.
P. O. Box 23571
Baton Rouge, Louisiana 70893

Mr. Robert D. Martin
U.S. NRC, Region IV
Parkway Central Plaza Building
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Enclosure

REFERENCE: ltr from J.E. Booker (GSUC) to H.R. Denton (NRC)
dtd May 15, 1985 (RBG-21,017)

The response to question #1 needs revision. The concern is the technical acceptability of the incorporation of Contingencies 2 and 7 of the BWROG Emergency Procedures Guidelines (EPGs) into step 3.3.6 of River Bend's EOP-0001, Revision 1. It seems that the two contingencies have different actions for similar conditions and both contingencies have not been adequately incorporated into this step. Provide justification for the approach proposed including the most current approved revision of EOP-0001 and other procedures referenced by EOP-0001 necessary to evaluate the incorporation of Contingencies 2 and 7 into EOP-0001. Any proposed changes to these procedures should also be provided.