



Log # TXX-92636  
Fil # 10110 (CP-92-020)  
# 903.9  
Ref # 10CFR50.55(e)

**TU ELECTRIC**

January 4, 1993

William J. Cahill, Jr.

*Group Vice President*

U. S. Nuclear Regulatory Commission

Attn: Document Control Desk

Washington, DC 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES) - UNIT 2  
DOCKET NO. 50-446  
CRACKS IN THE CONTAINMENT SPRAY SYSTEM  
SDAR: CP-92-020 (INTERIM REPORT)

Gentlemen:

On December 4, 1992, via facsimile, TU Electric notified the NRC of a reportable defect involving a 90 degree circumferential crack found in the base metal along the toe of a weld in the chemical eductor portion of the containment spray system. The evaluation was designated SDAR CP-92-020 and this letter is an interim report under the reporting requirements of 10CFR50.55(e). A detailed report will be submitted by January 11, 1992.

Sincerely,

William J. Cahill, Jr.

By: 

D. R. Woodlan

Docket Licensing Manager

CBC

c - Mr. J. L. Milhoan, Region IV  
Mr. B. E. Holian, NRR  
Resident Inspectors, CPSES (2)

070001

9301080127 930104  
PDR ADOCK 05000446  
S PDR

400 N. Olive Street L.B. 81 Dallas, Texas 75201

JE27 1/0