

June 13, 1985

PDR 610

Docket No. 50-344

Mr. Bart D. Withers
Vice President Nuclear
Portland General Electric Company
121 S. W. Salmon Street
Portland, Oregon 97204

Dear Mr. Withers:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION - INADEQUATE CORE COOLING
INSTRUMENTATION SYSTEM TMI ACTION ITEM II.F.2.3

The staff is continuing its review of PGE's submittals for TMI Item II.F.2.3. On February 2, 1984 the staff requested additional information which you responded to by letters dated March 12, 1984 and January 4, 1985. The staff has reviewed this information and found it is not complete. Further clarification is required as described in the enclosure, concerning the Core Exit Thermocouple System, the Subcooling Margin Monitors, and the Reactor Vessel Level Instrumentation System.

You are requested to provide this information within 30 days of receipt of this letter or within 15 days provide an explanation why this is not possible and an alternative schedule.

Should you have any questions concerning the enclosed request, please contact the Project Manager, Lisamarie Lazo, at (301) 492-7791.

The information requested in this letter affects fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

Edward J. Butcher, Acting Chief
Operating Reactors Branch No. 3
Division of Licensing

Enclosure:
Request for
Additional Information

cc w/enclosure:
See next page

Distribution:	Docket File	NRC & L PDRs	Branch Files	PKreutzer
LLazo	BGrimes	EJordan	EButcher	HThompson
ACRS 10	OELD			

ORB#3:DL
PKreutzer
6/13/85

ORB#3:DL
LLazo;ef
6/13/85

ORB#3:DL
EButcher
6/13/85

For

For

8506200352 850613
PDR ADOCK 05000344
P PDR

Mr. Bart D. Withers
Portland General Electric Company Trojan Nuclear Plant

cc:
Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Trojan Nuclear Plant
Post Office Box 0
Rainier, Oregon 97048

Robert M. Hunt, Chairman
Board of County Commissioners
Columbia County
St. Helens, Oregon 97501

William T. Dixon
Oregon Department of Energy
Labor and Industries Building
Room 111
Salem, Oregon 97310

Regional Administrator, Region V
U.S. Nuclear Regulatory Commission
Office of Executive Director for Operations
1450 Maria Lane, Suite 210
Walnut Creek, California 94596