

Official

MAY 22 1985

Duke Power Company
ATTN: Mr. H. B. Tucker, Vice President
Nuclear Production Department
422 South Church Street
Charlotte, NC 28242

Gentlemen:

SUBJECT: DOCKET NO. 50-369 AND 50-370 - MCGUIRE NUCLEAR STATION RADIOLOGICAL
EMERGENCY PLAN REVIEW

We have completed our review of Revisions 15 and 16 of the McGuire Radiological
Emergency Plan and Revisions 13 and 14 to the Duke Power Company Crisis
Management Plan.

Our review indicated that your emergency plans continue to meet the planning
standards of 10 CFR 50.47(b) and the requirements of Appendix E to 10 CFR 50.

Please be reminded that 10 CFR 50.54(q) requires NRC approval of any changes to
your plan which may decrease the effectiveness of the Plan. However, if your
safety review indicates no difference in emergency preparedness, then changes
can be made without NRC approval. In all cases, you should furnish copies of
each proposed change to the NRC in accordance with 10 CFR 50.54(q). Also, any
changes to the Emergency Plan Implementing Procedures should be made in
accordance with the requirements of 10 CFR 50, Appendix E, Section V
(Implementing Procedures).

Should you have any questions regarding this letter, please contact
Mr. A. L. Cunningham of our staff at 404/221-2605.

Sincerely,

Virgil L. Brownlee, Chief
Reactor Projects Branch 2
Division of Reactor Projects

cc: T. L. McConnell, Station Manager

bcc: NRC Resident Inspector
Document Control Desk
State of North Carolina

RII

ACunningham
5/20/85

RII

WCline
5/21/85

RII

DCollins
5/21/85

RII

CBarger
5/21/85

RII

HDance
5/21/85

8506200358 850522
PDR ADOCK 05000369
F PDR

IE 35 1/0