



THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 5000 - CLEVELAND, OHIO 44101 - TELEPHONE (216) 622-9800 - ILLUMINATING BLDG. - 55 PUBLIC SQUARE

Serving The Best Location in the Nation

June 7, 1985

PY--CEI/OIE-0066 L

MURRAY R. EDELMAN
VICE PRESIDENT
NUCLEAR

Mr. James G. Keppler
Regional Administrator, Region III
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

RE: Perry Nuclear Power Plant
Docket Nos. 50-440; 50-441
Overpressurization of
Isolated Volumes in Drywell
Post-LOCA [RDC 123(85)]

Dear Mr. Keppler:

As stated in our letter on this subject dated April 12, 1985, we are submitting this letter to advise you of our progress with regard to Deviation Analysis Report (DAR) 218.

Resolution of the problem concerning the Unit 1 drywell personnel airlock seals and associated inflation system has been completed through the corrective action taken for DAR 147.

We are currently awaiting General Electric's evaluation of the effect of increased pressures on components previously identified which would result from post-LOCA temperature elevations. Results of testing performed by General Electric on the ADS-SRVs indicate that the ADS-SRVs will operate at the higher pressures achievable during post-LOCA.

We will file our next report upon review and acceptance of the MSIV evaluation and ADS-SRV testing result from General Electric.

Please call if there are any additional questions.

Sincerely,

Murray R. Edelman
Vice President
Nuclear Group

MRE:pab

8506200390 850607
PDR ADDOCK 05000440
S PDR

JUN 10 1985

IE27
1/0

Mr. James G. Keppler

- 2 -

June 7, 1985
PY-CEI/OIE-0066 L

cc: J. A. Grobe
U.S. NRC-Site Office

D. E. Keating
U.S. NRC-Site Office

Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Records Center, SEE-IN
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 33039