

DAB

✓ has

NG + 1 DRSS

has

Iowa Electric Light and Power Company

May 30, 1985
NG-85-2395

Mr. James G. Keppler
Regional Administrator
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Subject: Duane Arnold Energy Center
Docket No: 50-331
Op. License No: DPR-49
National Pollutant Discharge Elimination
System (NPDES) Violation Report
Ref: Letter, L. Root to H. Denton, "License
Amendment 84 Regarding Water Quality
Requirements," NG-83-1424, April 25, 1983
File: A-107a, A-87g

Dear Mr. Keppler:

Per our referenced letter, Iowa Electric Light and Power Company agreed to submit to your office copies of all NPDES Violation Reports. Enclosed with this letter is a copy of the DAEC Sewage Treatment monthly monitoring report for April, 1985. This report contains one (1) violation of the NPDES permit effluent limits. This violation is:

- (1) April, 1985, total suspended solids monthly average = 31 mg/L. This violates the monthly average limit of 30 mg/L. However, the monthly average pounds of total suspended solids (3.9) did not exceed the effluent limit of 12.5.

This effluent violation is the result of the additional loading from the outage personnel. The increased loading will continue to be a problem until the end of our current refueling outage. During this period, Iowa Electric is making every effort to keep the sewage treatment plant in compliance with our NPDES effluent limits.

Should you have any questions regarding this matter, please contact me.

Very truly yours,

Richard W. McGaughey

Richard W. McGaughey
Manager, Nuclear Division

IT 23
1/1

8506200454 850530
PDR ADOCK 05000331
R PDR

RWM/SAR/ta*

Attachment: April, 1985, NPDES Monthly Monitoring Report

cc: S. Reith M. Thadani
L. Liu H. Denton
S. Tuthill NRC Resident Office

JUN 3 1985