

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1)	DOCKET NUMBER (2)	PAGE (3)
SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 2	0 5 0 0 0 3 6 1	1 OF 01

TITLE (4)
DELINQUENT SEVEN DAY LOCKED FIRE DOOR SURVEILLANCE

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)		
MONTH	DAY	YEAR	YEAR	SEQ. NUMBER	REV. NUMBER	MONTH	DAY	YEAR	FACILITY NAME	DOCKET NUMBER (9)	
05	06	85	85	030	00	06	03	85	UNIT 3	0 5 0 0 0 3 6 2	
										0 5 0 0 0 3 6 2	

OPERATING MODE (9)	THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 50.73 (Check one or more of the following) (11)										
1	20.402(b)		20.405(c)		50.73(a)(2)(iv)		73.71(b)				
POWER LEVEL (10) 1 0 0	20.405(a)(1)(i)		50.36(c)(1)		50.73(a)(2)(v)		73.71(c)				
	20.405(a)(1)(ii)		50.36(c)(2)		50.73(a)(2)(vi)		OTHER (Specify in Abstract below and in Text, NRC Form 366A)				
	20.405(a)(1)(iii)		X 50.73(a)(2)(i)		50.73(a)(2)(vii)(A)						
	20.405(a)(1)(iv)		50.73(a)(2)(ii)		50.73(a)(2)(vii)(B)						
	20.405(a)(1)(v)		50.73(a)(2)(iii)		50.73(a)(2)(viii)						

LICENSEE CONTACT FOR THIS LER (12)

NAME	TELEPHONE NUMBER
J. G. HAYNES, STATION MANAGER	711 4 4921-1717010

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE)	X NO	EXPECTED SUBMISSION DATE (15)	MONTH	DAY	YEAR

Abstract (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

Technical Specification 4.7.9.1.b requires verification of the position of each locked closed fire door every seven days.

On May 15, 1985, during a documentation review by the Emergency Services Organization of fire door surveillances, it was determined that the 7-day surveillance scheduled for May 4, 1985, was not performed and the 25% extension allowed in Technical Specification 4.0.2 was exceeded on May 6, 1985.

A review of the previous surveillance on April 27, 1985, and the subsequent surveillance on May 11, 1985, did not identify any deficiencies in the position of the locked fire doors. In addition, the administrative controls for the access of locked fire doors require, prior to access, that authorization from Emergency Preparedness be received in writing and a fire watch established. There is no evidence that these controls were violated; because of this it has been concluded that there was no significance to this event.

The cause of this event was oversight. The inspector failed to review the daily work schedule to determine if he had been assigned surveillances. As corrective action the inspector was disciplined and all other inspectors were made aware of this event. In addition, the administrative controls for verifying surveillance completion were strengthened to ensure compliance with the surveillance schedules.

IE22
1/1

Southern California Edison Company

SCE

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 95062

J. G. HAYNES
STATION MANAGER

June 3, 1985

TELEPHONE
(714) 865-1770

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Subject: Docket No. 80-361
30-Day Report
Licensee Event Report No. 85-030
San Onofre Nuclear Generating Station, Units 2 and 3

Pursuant to 10 CFR 50.73(a)(2)(i)(B), this submittal provides the required 30-day written Licensee Event Report (LER) for an occurrence involving a delinquent 7-day locked closed fire door surveillance. Since this occurrence involved fire doors on Units 2 and 3, a single LER for Unit 2 is enclosed per NUREG-1022. Neither the health and safety of plant personnel nor the health and safety of the public was affected by this event.

If you require any additional information, please so advise.

Sincerely,

J. G. Haynes

Enclosure: LER No. 85-030

cc: F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)
J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)
J. B. Martin (Regional Administrator, USNRC Region V)
Institute of Nuclear Power Operations (INPO)

IE22
11