



Carolina Power & Light Company

Brunswick Nuclear Project
P. O. Box 10429
Southport, N.C. 28461-0429

JAN 06 1993

FILE: B09-13510C
SERIAL: BSEP-93-0003

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

BRUNSWICK STEAM ELECTRIC PLANT UNIT 1 AND 2
DOCKET NO. 50-325 AND 50-324
LICENSE NO. DPR-71 AND DPR-62
INITIAL NOTIFICATION WITHIN 24 HOURS FOR
SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.7.7.1 AND
PURSUANT TO TECHNICAL SPECIFICATION 6.9.2 (1-SR-93-002)

Gentlemen:

Units 1 and 2 are in Cold Shutdown to support the Unit outages that started on April 21, 1992. The following summarizes a fire protection Limiting Condition of Operation that will be initiated to allow work on the Fire Suppression System:

On January 7, 1993, both Fire Suppression System fire pumps will be made Inoperable for approximately 8 hours to allow replacement of the isolation valve (2-FP-V79) and the associated instrument line. The instrumentation on this line supplies the automatic start signal for the fire pumps. While the fire pumps will not be Technical Specification Operable, the Diesel-driven fire pump will remain available and will be manually started and run as backup suppression until the auto start instrumentation can be restored. Additionally the following actions have been taken to coordinate and expedite the completion of the instrument line isolation valve replacement:

- The work activity has been preplanned.
- Personnel will be stationed to monitor diesel fire pump operation.
- The valve replacement will be worked continuously until completed.
- Parts have been reserved and verified.
- Prefabrication of instrument line/valve assembly has been completed.

110022


9301120004 930106
PDR ADOCK 05000324
S PDR

JE22 1/0

- As a precaution Welding and Burning will be minimized throughout the Plant Site until a second fire pump is available.
- Availability of the Southport Fire Department pumper/tanker to draft from the discharge canal has been verified.

Should you have any questions regarding this notification, please contact Mr. Glen Thearling at (919) 488-2038.

Very truly yours,

A handwritten signature in cursive script, appearing to read "Robert C. Godley".

R. C. Godley, Manager NRC Compliance

cc: Mr. S. D. Ebnetter
Mr. R. H. Lo
BSEP NRC Resident Office