



Log # TXX-93008  
File # 10010

TU ELECTRIC January 7, 1993

William J. Cahill, Jr.  
Group Vice President

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)  
DOCKET NO. 50-446  
CPSES MAJOR MILESTONE SCHEDULE AND UNIT 2  
PART 21 REVIEW LIST

- REF: 1) Conversation between T. A. Hope, TU Electric and  
L. A. Yandell of NRC Region IV on July 29, 1992
- 2) TU Electric letter logged TXX-92580 from  
W. J. Cahill, Jr. to the NRC, dated December 4, 1992

Gentlemen:

As previously discussed in Reference 1, attached is the CPSES Major Milestone Schedule and portions of the Part 21 Open Items List (OIL) of issues that are currently in review. Our latest report on this issue was Reference 2.

Note that the attached portion of the OIL is an internal coordination and tracking tool for selected CPSES activities. The description of the required action is an abbreviated summary of the scheduled activities and may not be completely representative of the actions required to complete the activity. In addition, the dates are not commitments, but represent proposed completion dates for planning purposes. For specific details regarding the attached activities and dates, please contact Tim Hope at (817) 897-6370.

Sincerely,

*William J. Cahill, Jr.*

William J. Cahill, Jr.

110024

By: *Roger D. Walker*  
Roger D. Walker  
Manager of Regulatory Affairs  
for NEO

9301120024 930107  
PDR ADOCK 05000446  
S PDR

*JE19 1/1*

TXX-93008  
Page 2 of 2

RHS/tg

Attachments

c - Mr. J. L. Milhoan, Region IV  
Mr. L. A. Yandell, Region IV  
Mr. B. E. Holian, NRR  
Resident Inspectors, CPSES (2)

OPEN CPSES ISSUES REPORT  
SECTION II: PART 21 CORRESPONDENCE (UNIT 2)

Page: 1  
Date: 01/05/93

OIL NUMBER	UNIT	TITLE / ACTION REQUIRED	STATUS	ORIGINEE	ASSIGNEE	DATES	ROY	MRP
P21-COOP-09/22/1992	1X2	COOPER INDUSTRIES REF: (VL-11197) VEHICLE SUPERCEEDING A PART NUMBER. ENGINEERING TO EVALUATE FOR CPSES APPLICABILITY.	OPEN CARBQ	NED/LIRI NCD/SE	P. SKIBA D. ZIMMER J. BENOYIN K. KHAMMA	Next Action: 12/15/92 Final Compl: 01/25/93		
P21-LIMI-12/07/1992	1X2	LIMITORQUE CORPORATION REF: (VL-13852) POTENTIAL P21 CONDITION SMR/SE-000, S-4B/SB/SEB-00 DECLUTCH SYSTEM ANOMALY. MOV/S WHICH ARE REQ'D TO OPERATE DURING A SEISMIC EVENT MAY EXHIBIT A LONGER STROKE TIME. THIS MALFUNCTION ONLY OCCURS DURING THE SEISMIC EVENT. AFTER VIBRATION STOP, THE ACTUATOR WILL RETURN TO PROPER OPERATION. ONE FORM FX-42-1563 DISPOSITIONED DCN-5381 REV. 1 ISSUED. THESE ACTIONS CONSIDERED TO BE POST FUEL LOAD.	OPEN CARBQ	NED/LIRI NCD/SE	P. SKIBA B. WITNROW	Next Action: 01/25/93 Final Compl: 01/25/93		

\*\*\*\*\*< END OF P21 REPORT (2) >\*\*\*\*\*

