

JAN 7 1993

DCD/DCB
(RIDS)

Docket No. 50-295
Docket No. 50-304

Commonwealth Edison Company
ATTN: Mr. L. O. DelGeorge
Vice President, Nuclear Oversight and
Regulatory Services
Executive Towers West III
1400 Opus Place, Suite 300
Downers Grove, IL 60515

Dear Mr. DelGeorge:

This refers to the routine safety inspection conducted by J. D. Smith, R. J. Leemon, R. B. Landsman, D. E. Jones, F. A. Maura, and J. R. Walker of this office from November 10 through December 21, 1992. The inspection included a review of activities authorized for your Zion Nuclear Generating Station. At the conclusion of the inspection, the findings were discussed with those members of your staff identified in the enclosed report.

The enclosed copy of our inspection report identifies areas examined during the inspection. Within these areas, the inspection consisted of a selective examination of procedure and representative records, observations, and interviews with personnel.

During this inspection, certain of your activities appeared to be in violation of NRC requirements. An previously unresolved item for an inadequate procedure for splitting of the component cooling water system in the event of a leak was determined to be a violation. As described in the enclosed inspection report, the violation was categorized at Severity Level V. A Notice of Violation is not being issued because the criteria specified in Sections III.A. and V.G.1 of the "General Statement of Policy and Procedures for NRC Enforcement Actions", Enforcement Policy, 10 CFR Part 2, Appendix C (1992) were satisfied.

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter and the enclosed inspection report will be placed in the NRC Public Document Room.

110016

9301120027 930107
PDR ADOCK 05000295
Q PDR

WBA
IEO
11

JAN 7 1993

We will gladly discuss any questions you have concerning this inspection.

Sincerely,

Original Signed by Martin J. Farber

Martin J. Farber, Chief
Reactor Projects Section 1A

Enclosure: Inspection Reports
No. 50-295/92032(DRP);
No. 50-304/92032(DRP)

cc w/enclosure:

R. Tuetken, Site Vice President
S. Kaplan, Regulatory Assurance
Supervisor
D. Farrar, Nuclear Regulatory Services
Manager
DCD/DCB (RIDS)
OC/LFDCB
Resident Inspectors, Zion, Braidwood,
Byron
R. Hubbard
J. McCaffrey, Chief, Public Utilities
Division
Mayor, City of Zion
Licensing Project Manager, NRR
R. Newmann, Office of Public Counsel,
State of Illinois Center
R. Thompson, Administrator, Wisconsin
Division of Emergency Government
State Liaison Officer

RILL
MJF
Farber