

Detroit
Edison

William S. Oraer
Executive Vice President
Nuclear Generation

Fermi 2
6400 North Dixie Highway
Newport, Michigan 48166
(313) 586-5201

Reg Guide 1.16



Nuclear
Operations

January 15, 1993
NRC-93-0001

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Reference: Fermi 2
NRC Docket No. 50-341
NRC Operating License No. NPF-43

Subject: Monthly Operating Status Report for December,
1992

Enclosed for your information and use is the Fermi 2 Monthly Operating Status Report for December, 1992. This report includes the Operating Data Report, Average Daily Unit Power Level, and the Summary of Unit Shutdowns and Power Reductions identified in NRC Regulatory Guide 1.16 and Fermi 2 Technical Specification 6.9.1.6.

If you have any questions, please contact Brian Stone, at
(313) 586-5148.

Sincerely,

Enclosure

cc: T. G. Colburn
A. B. Davis
D. R. Hahn
W. J. Kropp
M. P. Phillips
P. L. Torpey

9301210002 921231
PDR ADDCK 05000341
R PDR

JE24

OPERATING DATA REPORT

DOCKET NO. 50-341

COMPLETED BY B. J. Stone

DATE January 15, 1993

TELEPHONE (313) 586-5148

OPERATING STATUS

1. UNIT NAME: Fermi 2 | Notes: (1) Calculated using |
2. REPORTING PERIOD: December, 1992 | weighted averages to reflect |
3. LICENSED THERMAL POWER (MWt): 3430 | variations in rating (MDC and |
4. NAMEPLATE RATING (GROSS MWe): 1179 | DER). |
5. DESIGN ELECT RATING (Net MWe): 1116 | (2) To be revised following |
6. MAX DEPENDABLE CAP (GROSS MWe): 1110(2) | performance demonstration. |
7. MAX DEPENDABLE CAP (Net MWe): 1060 (2) |
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS NUMBER 3 THROUGH 7) SINCE
LAST REPORT, GIVE REASONS: _____
9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (MWe Net): _____
10. REASONS FOR RESTRICTION, IF ANY: _____

	THIS MONTH	YR TO DATE	CUMULATIVE
11. HRS IN REPORTING PERIOD	<u>744</u>	<u>8,784</u>	<u>43,310</u>
12. HRS REACTOR WAS CRITICAL	<u>549.8</u>	<u>7,139.5</u>	<u>32,403.2</u>
13. REACTOR RESERVE SHUTDOWN HRS	<u>0</u>	<u>0</u>	<u>0</u>
14. HOURS GENERATOR ON-LINE	<u>534.4</u>	<u>7,020.3</u>	<u>31,047.1</u>
15. UNIT RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
16. GROSS THERMAL ENERGY GEN (MWH)	<u>1,614,912</u>	<u>22,606,104</u>	<u>94,087,295.4</u>
17. GROSS ELECT ENERGY GEN (MWH)	<u>545,920</u>	<u>7,679,710</u>	<u>31,327,747</u>
18. NET ELECT ENERGY GEN (MWH)	<u>523,832</u>	<u>7,356,765</u>	<u>29,949,001</u>
19. UNIT SERVICE FACTOR	<u>71.8</u>	<u>79.9</u>	<u>71.7</u>
20. UNIT AVAILABILITY FACTOR	<u>71.8</u>	<u>79.9</u>	<u>71.7</u>
21. UNIT CAP FACTOR (USING MDC NET)	<u>66.4</u>	<u>79.0</u>	<u>64.6 (1)</u>
22. UNIT CAP FACTOR (USING DER NET)	<u>63.1 (1)</u>	<u>76.4 (1)</u>	<u>63.2 (1)</u>
23. UNIT FORCED OUTAGE RATE	<u>0</u>	<u>2.7</u>	<u>7.8</u>
24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, DURATION OF EACH):			
25. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP:			

26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION):

	FORECAST	ACHIEVED
INITIAL CRITICALITY	<u>N/A</u>	<u>N/A</u>
INITIAL ELECTRICITY	<u>N/A</u>	<u>N/A</u>
COMMERCIAL OPERATION	<u>N/A</u>	<u>N/A</u>

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-341
 UNIT FERMI 2
 DATE January 15, 1993
 COMPLETED BY E. Dawson
 TELEPHONE (313) 586-5027

Month December, 1992

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	<u>987</u>
2	<u>671</u>
3	<u>679</u>
4	<u>492</u>
5	<u>2</u>
6	<u>0</u>
7	<u>0</u>
8	<u>0</u>
9	<u>0</u>
10	<u>0</u>
11	<u>0</u>
12	<u>0</u>
13	<u>32</u>
14	<u>1037</u>
15	<u>1119</u>
16	<u>1110</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17	<u>1117</u>
18	<u>1121</u>
19	<u>1118</u>
20	<u>1123</u>
21	<u>1124</u>
22	<u>1121</u>
23	<u>1119</u>
24	<u>1125</u>
25	<u>1071</u>
26	<u>916</u>
27	<u>960</u>
28	<u>957</u>
29	<u>957</u>
30	<u>961</u>
31	<u>965</u>

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-341DATE January 15, 1993UNIT NAME Fermi 2COMPLETED BY B. J. StoneTELEPHONE (313) 586-5148REPORT MONTH December, 1992

NO. (6)	DATE	TYPE (1)	DUR (HRS) (7)	REASON (2)	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER (3)	LER NO.	SVS CODE (4)	COMP CODE (5)	CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE
R 92-03	12/02/92	F	0	A	5	N/A	SE	EXJ/PSP	Recirculation runback on loss of Heater Drains.
R 92-04	12/04/92	S	0	B	1	N/A	SE	EXJ/PSP	Power reduction to monitor #4 Feedwater Heater Extraction Steam Line.
S 92-05	12/05/92	S	209.6	A	1	N/A	SE	EXJ/PSP	Repair of extraction steam line rupture.

(1) F: FORCED
S: SCHEDULED(2) REASON:
A - EQUIPMENT FAILURE (EXPLAIN)
B - MAINTENANCE OR TEST
C - REFUELING
D - REGULATORY RESTRICTION
E - OPERATOR TRAINING & LICENSE EXAMINATION
F - ADMINISTRATIVE
G - OPERATIONAL ERROR (EXPLAIN)
H - OTHER (EXPLAIN)(3) METHOD:
1 - MANUAL
2 - MANUAL SCRAM
3 - AUTOMATIC SCRAM
4 - CONTINUED
5 - REDUCED LOAD
0 - OTHER(4) INSTRUCTIONS FOR
PREPARATION OF DATA
ENTRY SHEETS FOR LICENSEE
EVENT REPORT (LER) FILE
(NUREG-1022)

(5) SAME SOURCE AS (4)

(6) R - PREFIX INDICATES POWER
REDUCTION.
S - PREFIX INDICATES PLANT
SHUTDOWN.(7) DURATION OF REDUCTIONS
REPORTED AS ZERO PER REG.
GUIDE 1.16 REV. 4