

November 24, 1992

Docket No. 50-331

Mr. Lee Liu
Chairman of the Board and
Chief Executive Officer
Iowa Electric Light and Power Company
P. O. Box 351
Cedar Rapids, Iowa 52406

DISTRIBUTION

Docket File OGC
PD33 Rdg File ACRS(10)
NRC & LPDRs RIII DRP
JRoe AMasciantonio
TKing
JHannon
CShiraki
RPulsifer
PKreutzer
PD33 Gray Files

Dear Mr. Liu:

SUBJECT: DUANE ARNOLD ENERGY CENTER - RESPONSE TO NRC BULLETIN 92-01,
SUPPLEMENT 1, "FAILURE OF THERMO-LAG 330 FIRE BARRIER SYSTEM"
(TAC NO. M83872)

By letter dated October 1, 1992, you provided a response to NRC Bulletin 92-01 for the Duane Arnold Energy Center (DAEC). Your response stated that compensatory measures have been implemented consistent with the plant Technical Specifications. You also stated that you would continue to monitor industry testing for new data that should be applied to your Thermo-Lag installations and would actively participate in NUMARC efforts to reach a final resolution.

We have reviewed your response and find it acceptable. Please inform us of the completion of any additional corrective actions that are taken. Further NRC review, if any, will be performed by inspection or audit.

This action closes TAC No. M83872.

Sincerely,

ORIGINAL SIGNED BY:

Robert M. Pulsifer, Project Manager
Project Directorate III-3
Division of Reactor Projects - III/IV/V
Office of Nuclear Reactor Regulation

cc: See next page

OFFICE	LA:PD33	PM:PD33	D:PD33	<i>SPUB</i> <i>SRX</i> <i>CF</i>
NAME	PKreutzer	RPulsifer:jd	JHannon	<i>for</i> <i>CMcCracken</i> <i>P. 2</i>
DATE	11/12/92	11/15/92	11/24/92	1/18/92

OFFICIAL RECORD COPY

FILENAME: G:\DUANEARN\DUA83872.LTR

300052
9212040311 921124
PDR ADOCK 05000331
G PDR

1001
1/0
NRC FILE CENTER COPY

Mr. Lee Liu
Iowa Electric Light and Power Company

Duane Arnold Energy Center

cc:

Jack Newman, Esquire
Kathleen H. Shea, Esquire
Newman and Holtzinger
1615 L Street, N.W.
Washington, D.C. 20036

Chairman, Linn County
Board of Supervisors
Cedar Rapids, Iowa 52406

Iowa Electric Light and Power Company
ATTN: David L. Wilson
Plant Superintendent, Nuclear
3277 DAEC Road
Palo, Iowa 52324

Mr. John F. Franz, Jr.
Vice President, Nuclear
Duane Arnold Energy Center
3277 DAEC Road
Palo, Iowa 52324

Mr. Keith Young
Manager, Nuclear Licensing
Duane Arnold Energy Center
3277 DAEC Road
Palo, Iowa 52324

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
Rural Route #1
Palo, Iowa 52324

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Mr. Stephen N. Brown
Utilities Division
Iowa Department of Commerce
Lucas Office Building, 5th Floor
Des Moines, Iowa 50319