

JUN 2 5 1985

Docket No. 50-461

Mr. Frank A. Spangenberg  
Director of Nuclear Licensing  
and Configuration Management  
Clinton Power Station  
P.O. Box 306  
Mail Code V920  
Clinton, Illinois 61727

Distribution

Docket  
BRC PDR  
Local PDR  
PRC System  
NSIC  
LB#2 Reading  
EHylton  
BSiegel  
WButler  
ACRS (16)  
JPartlow  
BGrimes  
EJordan

Dear Mr. Spangenberg:

SUBJECT: USE OF ASME CODE CASE N-71-13 FOR THE CLINTON POWER STATION UNIT 1

The staff has completed its review of your request for authorization to use ASME Code N-71-13 for application at the Clinton Power Station Unit 1 as discussed in your letter Serial No. U-600061, dated May 22, 1985.

Code Case N-71-13, "Additional Materials for Subsection NF, Classes 1, 2, 3, and MC Component Supports Fabricated by Welding, Section III, Division 1", is an acceptable Code Case which is approved as written with no additional requirements other than those specified in the Code Case. The Code Case will be endorsed by the NRC in a future revision of Regulatory Guide 1.85, "Material Code Case A Acceptability ASME Section III, Division 1".

Code Case N-71-13 may therefore be used at Clinton Power Station Unit 1 within the limitations stated in the "Inquiry" and "Reply" section of the Code Case. Use of the Code Case should be documented in a future Amendment to the FSAR.

If you have any questions regarding the resolution of this issue, please contact your project manager.

Sincerely,

Walter R. Butler, Chief  
Licensing Branch No. 2  
Division of Licensing

cc: R. Kirkwood  
R. Bosnak  
J. Brammer  
F. Cherney

8507030610 850625  
PDR ADOCK 05000461  
A PDR

OFFICE	LB#2/DL	LB#2/DL/BC				
NAME	BSiegel.mk	WButler				
DATE	6/1/85	6/2/85				