

May 20, 1985

Docket No. 50-193

Mr. A. Francis DiMeglio, Director  
Nuclear Science Center  
Rhode Island Atomic Energy Commission  
South Ferry Road  
Narragansett, Rhode Island 02882

Dear Mr. DiMeglio:

SUBJECT: AMENDMENT NO. 14 TO OPERATING LICENSE NO. R-95

The Commission has issued the enclosed Amendment No. 14 to Facility Operating License No. R-95 for the Rhode Island Atomic Energy Commission. The amendment consists of changes to the technical specifications in response to your application dated April 24, 1985.

The amendment changes the allowable pH range of the secondary coolant water from 5.5-7.5 to 5.5-9.

Copies of the amendment and the Safety Evaluation are enclosed.

Sincerely,

Original signed by  
Cecil O. Thomas, Chief  
Standardization and Special  
Projects Branch  
Division of Licensing

Enclosures:

1. Amendment No. 14
2. Safety Evaluation

cc: See next page

DISTRIBUTION:

Docket File

NRD PDR

DCS

SSPB Reading

Region I

P. Anderson (3)

H. Bernard

H. Berkow

D. Crutchfield

H. Thompson

D. Eisenhut

H. Denton

OELD

E. Jordan

J. Partlow

T. Barnhart (4)

OPA, C. Miles

ACRS

J. Hyder, LANL

RDiggs/LTremper

DL:SSPB  
PAnderson:ac  
05/10/85

DL:SSPB  
HBernard  
05/10/85

DL:SSPB  
HBerkow  
05/15/85

DL:SSPB  
CThomas  
05/20/85

OELD  
M. Karman  
05/16/85

8505280550 850520  
PDR ADOCK 05000193  
P PDR



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

May 20, 1985

Docket No. 50-193

Mr. A. Francis DiMeglio, Director  
Nuclear Science Center  
Rhode Island Atomic Energy Commission  
South Ferry Road  
Narragansett, Rhode Island 02882

Dear Mr. DiMeglio:

SUBJECT: AMENDMENT NO. 14 TO OPERATING LICENSE NO. R-95

The Commission has issued the enclosed Amendment No. 14 to Facility Operating License No. R-95 for the Rhode Island Atomic Energy Commission. The amendment consists of changes to the technical specifications in response to your application dated April 24, 1985.

The amendment changes the allowable pH range of the secondary coolant water from 5.5-7.5 to 5.5-9.

Copies of the amendment and the Safety Evaluation are enclosed.

Sincerely,

*Cecil O. Thomas*

Cecil O. Thomas, Chief  
Standardization and Special  
Projects Branch  
Division of Licensing

Enclosures:

1. Amendment No. 14
2. Safety Evaluation

cc: See next page

President, Town Council  
Town of Narragansett  
Town Hall  
Narragansett, Rhode Island 02882

Honorable J. Joseph Garrahy  
Governor of Rhode Island  
Providence, Rhode Island 02903

State of Rhode Island  
Energy Office  
ATTN: S. Killeher  
80 Dean Street  
Providence, Rhode Island 02903

Attorney General  
Department of Attorney General  
411 Providence County Courthouse  
Providence, Rhode Island 02903