



Northern States Power Company

414 Nicollet Mall
Minneapolis, Minnesota 55401
Telephone (612) 330-5500

May 21, 1985

Director
Office of Nuclear Reactor Regulation
U S Nuclear Regulatory Commission
Washington, DC 20555

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
Docket Nos. 50-282 License Nos. DPR-42
50-306 DPR-60

Unit 1 Inservice Inspection Summary Report

Attached for your review are four copies of the report, "Inservice Inspection - Examination Summary, Prairie Island Nuclear Generating Plant - Unit 1, January 14, 1985 thru February 22, 1985". This is the first inservice inspection conducted for inspection period one of the second ten year interval.

This report identifies the components examined, the examination methods used, the examination number and summarizes the examination results of each of the following areas:

1. Balance of Plant
 - a) Pressure retaining components and supports of the reactor coolant and associated systems classified as ASME Class 1 and ASME Class 2.
 - b) FSAR augmented examinations of main steam and feedwater systems.
2. Reactor pressure vessel examinations.
3. Eddy Current Examination of Steam Generator Tubing. Seven tubes in No. 11 steam generator and nine tubes in No. 12 steam generator were mechanically plugged.
4. Safety injection line replacement.

The evaluation of the results from the inservice examinations indicated that integrity of the systems has been maintained.


8505290167 850521
PDR ADDCK 05000282
Q PDR

A047
1/4

Dir of NRR
May 21, 1985
Page 2

Northern States Power Company

This report is being submitted in accordance with Prairie Island ASME Code Section XI Inservice Inspection and Testing Program. As noted in that program, submittal of the attached summary is intended to satisfy the inspection reporting requirements contained in IWA-6220 of Section XI of the ASME Code.


David Musolf
Manager - Nuclear Support Services

DMM/EFE/1e

- c: Regional Administrator-III, NRC (2 copies of attachment)
- NRR Project Manager, NRC (1 copy of attachment)
- Resident Inspector, NRC (w/o attachment)
- G Charnoff (w/o attachment)
- H Baron, Chief Boiler Insp., State of MN (1 copy of attachment)
- S Tact, Hartford Ins. (1 copy of attachment)

Attachment