

APPENDIX A
NOTICE OF DEVIATION

Arkansas Power & Light Company
Arkansas Nuclear One Units 1 and 2

Dockets: 50-313; 50-368
Licenses: DPR-51; NPF-6

Based on the results of an NRC inspection conducted during the period of April 15-19, 1985, and in accordance with NRC Enforcement Policy (10 CFR Part 2, Appendix C), 49 FR 8583, dated March 8, 1984, the following deviation was identified.

Continuous Air Monitoring

The licensee committed in ANO, Unit 1 Final Safety Analysis Report (FSAR), Section 11.3.2.3 and Unit 2 FSAR, Section 12.4.2.3 to have four continuous air samplers per unit capable of continuously monitoring and recording particulate and gaseous activity.

Contrary to the above, the NRC inspector determined on April 19, 1985, that only two continuous air samplers were operable with the necessary characteristics to satisfy the ANO, Units 1 and 2 FSAR commitments. (50-313/8509-01; 50-368/8509-01)

Arkansas Power and Light Company is hereby requested to submit to this office, within 30 days of the date of this Notice of Deviation, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further deviation from commitments made to the Commission; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

Dated: MAY 22 1985

8505290190 850522
PDR ADDCK 05000313
Q PDR