

PDR

February 1, 1974

B. H. Grier, Assistant Director for Construction & Operation, RO
AVERAGE POWER RANGE MONITORS

We have reviewed the matter concerning APRM rod block and scram settings that you pointed out in your memorandum of January 17, 1974. We agree with the position that you have stated. If any licensee believes that some limit or range other than that stated in the specification is appropriate, please advise him to submit a request for technical specification change, with supporting safety analysis.

181

Donald J. Skovholt
Assistant Director for
Operating Reactors
Directorate of Licensing

cc: V. Stello, L
D. L. Ziemann, L
R. H. Vollmer, L
G. Fiorelli, RO:III
R. J. McDermott, RO

DISTRIBUTION
Central Files
RP Reading
DJSkovholt

*Yellowed in 2-1-74
38.1*

MHS-3-8-1

9212070403 740201
PDR ADDOCK 05000263
P PDR

OFFICE ▶	TC:L	ADOR:L				
SURNAME ▶	TJCarter:bsp	DJSkovholt				
DATE ▶	2/1/74	2/1/74				