

MATERIALS LICENSE

Pursuant to the Atomic Energy Act of 1954, as amended, the Energy Reorganization Act of 1974 (Public Law 93-438), and Title 10, Code of Federal Regulations, Chapter I, Parts 30, 31, 32, 33, 34, 35, 40 and 70, and in reliance on statements and representations heretofore made by the licensee, a license is hereby issued authorizing the licensee to receive, acquire, possess, and transfer byproduct, source, and special nuclear material designated below; to use such material for the purpose(s) and at the place(s) designated below; to deliver or transfer such material to persons authorized to receive it in accordance with the regulations of the applicable Part(s). This license shall be deemed to contain the conditions specified in Section 183 of the Atomic Energy Act of 1954, as amended, and is subject to all applicable rules, regulations and orders of the Nuclear Regulatory Commission now or hereafter in effect and to any conditions specified below.

Licensee		
1. Niagara Mohawk Power Corporation	3. License number	31-20816-01
2. 300 Erie Boulevard, West Syracuse, New York 13202	4. Expiration date	April 30, 1990
	5. Docket or Reference No.	030-22118
6. Byproduct, source, and/or special nuclear material	7. Chemical and/or physical form	8. Maximum amount that licensee may possess at any one time under this license
A. Any byproduct material with Atomic Nos. 3-83 inclusive except:	A. Any	A. No single nuclide to exceed 100 millicuries, total 1 curie
B. Antimony 124	B. Sealed neutron startup sources (G.E. Dwg. No. 112-C3666)	B. No single source to exceed 3300 curies, total 21,000 curies
C. Plutonium-239	C. Sealed sources	C. No single source to exceed 5 microcuries, total 25 microcuries (.41 milligrams)
D. Americium 241	D. Any	D. 5 millicuries total
9. Authorized use		
A. For calibration and checking of radiation measurement equipment.		
B. For possession and storage in the source shipping cask. (Model No. GE-1500)		
C. and D. For calibration and checking of radiation measurement equipment.		

CONDITIONS

10. Licensed material shall be used only at the licensee's facilities, Nine Mile Point Nuclear Station Unit 2, Lake Road, Town of Scriba, New York.
11. The licensee shall comply with the provisions of Title 10, Chapter 1, Code of Federal Regulations, Part 19, "Notices, Instructions, and Reports to Workers; Inspections" and Part 20, "Standards for Protection Against Radiation."
12. Licensed material shall be used by, or under the supervision of, the Radiation Protection Manager.

8505290275 850507
REG1 LIC30
31-20816-01 PDR

"OFFICIAL RECORD COPY"

ML10

**MATERIALS LICENSE
SUPPLEMENTARY SHEET**

License number

31-20816-01

Docket or Reference number

030-22118

(Continued)

CONDITIONS

13. A. (1) Each sealed source acquired from another person and containing licensed material, other than Hydrogen 3, with a half-life greater than thirty days and in any form other than gas shall be tested for contamination and/or leakage prior to use. In the absence of a certificate from a transferor indicating that a test has been made within six months prior to the transfer, a sealed source received from another person shall not be put into use until tested.
- (2) Notwithstanding the periodic leak test required by this condition, any licensed sealed source is exempt from such leak tests when the source contains 100 microcuries or less of beta and/or gamma emitting material or 10 microcuries or less of alpha emitting material.
- (3) Except for alpha sources, the periodic leak test required by this condition does not apply to sealed sources that are stored and not being used. The sources excepted from this test shall be tested for leakage prior to any use or transfer to another person unless they have been leak tested within six months prior to the date of use or transfer.
- B. Each sealed source fabricated by the licensee shall be inspected and tested for construction defects, leakage, and contamination prior to use or transfer as a sealed source. If the inspection or test reveals any construction defects or 0.005 microcurie or greater of contamination, the source shall not be used or transferred as a sealed source until it has been repaired, decontaminated and retested.
- C. Each sealed source containing licensed material, other than Hydrogen 3, with a half-life greater than thirty days and in any form other than gas shall be tested for leakage and/or contamination at intervals not to exceed six months except that each source designed for the purpose of emitting alpha particles shall be tested at intervals not to exceed three months.
- D. The test shall be capable of detecting the presence of 0.005 microcurie of radioactive material on the test sample. The test sample shall be taken from the sealed source or from the surfaces of the device in which the sealed source is permanently or semi-permanently mounted or stored on which one might expect contamination to accumulate. Records of leak test results shall be kept in units of microcuries and maintained for inspection by the Commission.
- E. If the test required by Subsection A. or C. of this condition reveals the presence of 0.005 microcurie or more of removable contamination, the licensee shall immediately withdraw the sealed source from use and shall cause it to be decontaminated and repaired or to be disposed of in accordance with Commission regulations. A report shall be filed within 5 days of the test with the U.S. Nuclear Regulatory Commission, Region I, 631 Park Avenue, King of Prussia, Pennsylvania 19406, describing the equipment involved, the test results, and the corrective action taken.

**MATERIALS LICENSE
SUPPLEMENTARY SHEET**

License number

31-20816-01


Docket or Reference number

030-22118

(Continued)

CONDITIONS

14. The licensee shall conduct a physical inventory every six (6) months to account for all sealed sources received and possessed under the license. The records of the inventories shall be maintained for two (2) years from the date of the inventory for inspection by the Commission, and shall include the quantities and kinds of byproduct material, manufacturer's name and model numbers, location of sealed sources and the date of the inventory.
15. This license does not authorize the insertion of neutron sources into a nuclear reactor.
16. Except as specifically provided otherwise by this license, the licensee shall possess and use licensed material described in Items 6, 7, and 8 of this license in accordance with statements, representations, and procedures contained in application dated February 26, 1985 and telecopy transmittal on April 2, 1985. The Nuclear Regulatory Commission's regulations shall govern the licensee's statements in applications or letters, unless the statements are more restrictive than the regulations.



For the U.S. Nuclear Regulatory Commission

Original Signed By:

John E. Glenn

By

Nuclear Materials Safety and
Safeguards Branch, Region I
King of Prussia, Pennsylvania 19406

MAY 07 1985

Date