



Target Rock Corporation, 1966E Broadhollow Rd., P.O. Box V, Farmingdale, N.Y. 11735-0917

SUBSIDIARY CURTISS-WRIGHT CORPORATION

C13137

November 25, 1992

United States Nuclear Regulatory Commission  
Director, Office Of Inspection & Enforcement  
Document Control Center  
Washington, DC 20555

Attention: Dr. Gail Marcus  
cc: Nancy Campbell, Stephen Mathews

Subject: Target Rock Corporation Service Bulletin #9207  
(Cracked Disc Retaining Nuts in Target Rock Manual  
and Motor Operated Valves)

Dear Dr. Marcus:

Enclosed herewith is a copy of the subject service bulletin, a list of all Nuclear Plant recipients, and a copy of the transmittal letter sent to them.

Note that Mr. Steven Mathews had been advised earlier and a copy of the Target Rock drawing of the valves affected at Arkansas Nuclear One sent to him.

Please call the undersigned if additional information is required.

Sincerely,

TARGET ROCK CORPORATION

*Vito Liantonio*

Vito Liantonio  
Manager, Commercial Engineering

cc: R. Clayden E. Bajada  
R. Langseder S. Karidas  
K. Wenzel File  
E. Champey

KW:hk

9212080032 921125  
PDR MISC  
9212080032 PDR

Telephone (516) 293-3800

ADD: W. Haass

44. Ent.

FAX (516) 293-6144

DF03



Target Rock Corporation, 1966E Broadhollow Rd., P.O. Box V, Farmingdale, N.Y. 11735-0917

SUBSIDIARY, CORTISS-WRIGHT CORPORATION

C13138

November 25, 1992

\*Customer\*  
\*Address#1\*  
\*Address#2\*  
\*Address#3\*  
\*City\*, \*State\* \*Zip\*

Attention: \*Contact Person\*  
\*Department\*

Subject: Target Rock Corporation Service Bulletin #9207  
(Cracked Disc Retaining Nuts in Target Rock Manual  
and Motor Operated Valves)

Gentlemen:

Attached hereto is a copy of the subject service bulletin. The cracks were observed at Arkansas Nuclear One by Entergy Operations, Inc. Personnel and immediately replaced with spare hardware. This bulletin advises all plants affected and offers a solution to rectifying the problem. Note that the Nuclear Regulatory Commission (Vender Inspection Branch) has been included in this mailing and was previously advised when the problem was discovered.

Target Rock Service personnel are available should assistance be required to conduct the inspections.

Please call the undersigned or Mr. Kurt Wenzel, Manager, Commercial Nuclear Products, if further information is needed.

Sincerely,

TARGET ROCK CORPORATION

*Vito Liantonio*

Vito Liantonio  
Manager, Commercial Engineering

cc: R. Clayden	E. Bajada
R. Langseder	J. Karidas
K. Wenzel	File
E. Champey	

KW:hk

Address List TRC Service Bulletin 19207  
11/25/92

J. D. Alderink  
CONSUMERS POWER CO.  
Palisades Nuclear Plant  
27780 Blue Star Highway  
Covert MI 49043

Peggy Burgard  
Materials Technical  
ENTERGY OPERATIONS, INC.  
Waterford Nuclear 3  
P.O. Box B  
Killona LA 70066-0751

Manager  
Industry Events Review  
ENTERGY OPERATIONS, INC.  
Arkansas Nuclear One  
Route 3, Box 137G  
South Jct. of Hwys. U.S. 64W & Ark. 333S  
Russellville AR 72801

R. A. Symes JNA-JD  
Quality Manager, Juno Beach  
FLORIDA POWER & LIGHT CO.  
P.O. Box 14000  
Juno Beach FL 33408

Manager  
Nuclear Oversight Division  
SOUTHERN CALIFORNIA EDISON CO.  
San Onofre Nuclear Generating Station  
P.O. Box 128  
San Clemente CA 92672

Carl Winton  
TENNESSEE VALLEY AUTHORITY  
LP 5N 156B  
1101 Market Street  
Chattanooga TN 37402-2801

M. J. Fecht, Manager  
Nuclear Experience Review/ISE  
TENNESSEE VALLEY AUTHORITY  
1101 Market Street  
LP 5B  
Chattanooga TN 37402-2801

Address List TRC Service Bulletin 29207  
11/25/92

R. E. Malone  
Purchasing Department RM58  
WASHINGTON PUBLIC POWER SUPPLY SYSTEM  
WNP-2  
P.O. Box 968  
Mail Drop 989  
Richland WA 99352