



SMUD

SACRAMENTO MUNICIPAL UTILITY DISTRICT ☐ 6201 S Street, P.O. Box 15830, Sacramento CA 95852-1830, (916) 452-3211
AN ELECTRIC SYSTEM SERVING THE HEART OF CALIFORNIA

RJR 85-251

May 22, 1985

DIRECTOR OF NUCLEAR REACTOR REGULATION
ATTN: HUGH L THOMPSON JR, DIRECTOR
DIVISION OF LICENSING
U S NUCLEAR REGULATORY COMMISSION
WASHINGTON DC 20555


DOCKET NO. 50-312
LICENSE NO. DPR-54
SUBJECT: ADDITIONAL INFORMATION FOR PROPOSED AMENDMENT 112, REVISION 1

By letter dated April 26, 1985, the Sacramento Municipal Utility District revised its Operating License DPR-54 by submitting Proposed Amendment 112, Revision 1.

Per the request of Syd Miner, Rancho Seco's Project Manager, the District is submitting a copy of the Spent Fuel Cooling System Operating Procedure to aid the Commission in its review process.

This Proposed Amendment 112, Revision 1 involved adding a Limiting Condition for operation for the Spent Fuel Pool. Specifically, the coolant level of the Spent Fuel Pool will be continuously monitored so that if the level falls at or below the Low-Low Level alarm of 37 feet 6 inches, and the Spent Fuel Pool cooling system becomes inoperable, one train of the Decay Heat Removal System will be put into service.

Should you require any further information or have any questions with regard to the Spent Fuel Pool Limiting Condition for Operation, please contact Mr. Ron W. Colombo at Rancho Seco Nuclear Generating Station Unit No. 1.


R. J. Rodriguez
Assistant General Manager,
Nuclear

8505290432 850522
PDR ADOCK 05000312
P PDR

A001
111