



KANSAS GAS AND ELECTRIC COMPANY

GLENN L. KOESTER
VICE PRESIDENT - NUCLEAR

May 21, 1985

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

KMLNRC 85-121
Re: Docket No. STN 50-482
Subj: Technical Specifications

Dear Mr. Denton:

Transmitted herewith are changes to the Wolf Creek Technical Specifications. Kansas Gas and Electric Company (KG&E) requests incorporation of these changes into the Wolf Creek Technical Specifications for issuance with the Wolf Creek full power license.

Yours very truly,

Glenn L. Koester
Vice President - Nuclear

GLK:dab

xc: PO'Connor (2), w/a
JCummins, w/a

8505290545 850521
PDR ADOCK 05000482
P PDR

13001
1/1

STATE OF KANSAS)
) SS
CITY OF WICHITA)

Glenn L. Koester, of lawful age, being first duly sworn upon oath says that he is Vice President - Nuclear and an Officer of Kansas Gas and Electric Company; that he has read the foregoing document and knows the content thereof; that he has executed the same for and on behalf of said Company with full power and authority to do so; and that the facts therein stated are true and correct to the best of his knowledge, information and belief.

By Glenn L. Koester
Glenn L. Koester
Vice President - Nuclear

SUBSCRIBED and sworn to before me this

21st day of May, 1985.



Janis L. Dodge
Notary Public
Expiration Date 9.12.87

Justification for Changes to Technical Specification Table 3.8-1

KG&E was notified by Bechtel Power Corporation of a review they performed on the Wolf Creek Technical Specification Table 3.8-1. As a result of their review, the following items were identified.

- Low voltage power circuits lacking the backup protection required by Regulatory Guide 1.63. The design has been modified to comply with Regulatory Guide 1.63.
- Ten circuits originally provided with protection in accordance with Regulatory Guide 1.63 but not included in Table 3.8-1.
- Temporary circuits associated with Wolf Creek's special instrumented steam generator which are now permanent circuits.
- Concerns raised in regards to meeting the requirements of Regulatory Guide 1.106 as well as Regulatory Guide 1.63. Design changes have been made.
- Editorial changes to correct typos and clarify information.

Informational LER 85-017-00 (ULNRC 1082, 04/22/85) submitted by Union Electric for Callaway provides background information on these changes.

KG&E requests these changes to be incorporated into Wolf Creek's Technical Specifications for issue with the full power license.