



Nuclear Group
P.O. Box 4
Shippingport, PA 15077-0004

Telephone (412) 393-6000

June 27, 1985

Director of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Attn: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing
Washington, DC 20555

Reference: Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
Proposed Operating License Change Request No. 34, Revision 2

Gentlemen:


Enclosed are:

1. Three (3) originals and thirty-seven (37) copies of an Application for Amendment to our Operating License to allow use of the Low Head Safety Injection pump with an open RCS vent in place of a charging pump when the plant is in Mode 5 or 6.
2. Forty (40) copies of documents designated Attachments A and B which set forth the change in Technical Specifications and its no significant hazards determination.

The proposed changes would allow the charging pumps to be removed from service during the next refueling outage for maintenance and ISI examination. Our previous submittal (No. 34 Revision 1) provided notification that we were evaluating the Westinghouse "Pressurizer Bubble Cold Overpressure Analysis Report" to determine if an increase in the PORV setpoint was justified. However, we have determined this change could be the subject of a separate application and should not delay your review. Therefore, your review should proceed with the applicable pages provided by our previous submittal replaced with those enclosed.

This is a revision to a previous submittal for which a license fee was provided, therefore, we have determined that no additional license amendment application fee is required.

Very truly yours,


J. J. Carey
Vice President, Nuclear

8507080191 850627
PDR ADOCK 05000334
P PDR

Handwritten initials:
A-001
11

Beaver Valley Power Station, Unit No. 1
Docket No. 50334, License No. DPR-66
Proposed Operating License Change Request No. 34, Revision 2
Page 2

cc: Mr. W. M. Troskoski, Resident Inspector
U. S. Nuclear Regulatory Commission
Beaver Valley Power Station
Shippingport, PA 15077

U. S. Nuclear Regulatory Commission
c/o Document Management Branch
Washington, DC 20555

Director, Safety Evaluation & Control
Virginia Electric & Power Company
P. O. Box 26666
One James River Plaza
Richmond, VA 23261

Mr. Thomas M. Gerusky, Director
Bureau of Radiation Protection
Pennsylvania Department of Environmental Resources
P. O. Box 2063
Harrisburg, PA 17120