

In Reply Refer To:  
Dockets: 50-445/84-45

JUL 01 1985

Texas Utilities Electric Company  
ATTN: M. D. Spence, President, TUGCO  
Skyway Tower  
400 North Olive Street  
Lock Box 81  
Dallas, Texas 75201

Gentlemen:

We have reviewed your letter of April 15, 1985, in response to our letter and the attached Notice of Violation dated March 21, 1985. As a result of our review, we find that additional information, as discussed with your Mr. R. A. Jones on April 25, 1985, is needed. Specifically, your corrective action does not address all of the plant fluid flow and level detectors which may require maintenance and are under high pressure, subject to elevated temperature, or subject to radiological control. We also fail to understand why only the reference leg valves are to be tagged, and no reference was made as to the identification of the other instrument valves.

Please provide the supplemental information regarding activities associated with plant differential pressure detectors and tagging of all instrument valves, within 30 days of the date of this letter.

Sincerely,

"Original Signed By:  
D. R. HUNTER"

D. R. Hunter, Chief  
Reactor Project Branch 2

cc: (See next page)

RPB2/B *DM*  
DMHunnicut:gb  
6/5/85

RPB2 *DR*  
DRHunter  
6/6/85

DRS&P *RP*  
RPDenise  
6/28/85

NRR *VM*  
VNoohan  
6/24/85

8507080218 850701  
PDR ADOCK 05000445  
G PDR

IE01

Texas Utilities Electric Company

2

Texas Utilities Electric Company

ATTN: B. R. Clements, Vice  
President, Nuclear

Skyway Tower  
400 North Olive Street  
Lock Box 81  
Dallas, Texas 75201

Texas Utilities Electric Company

ATTN: J. W. Beck, Manager,  
Licensing

Skyway Tower  
400 North Olive Street  
Lock Box 81  
Dallas, Texas 75201

Texas Radiation Control Program Director

bcc to DMB (IE01)

bcc distrib. by RIV:

\*RPB2

\*RRI-OPS

\*RRI-CONST

\*Section Chief (RPB2/B)

V. Noonan, NRR

S. Treby, ELD

\*RIV File

\*MIS System

\*RSTS Operator

\*EP&RPB

R. Denise, D/DRSP

R. Martin, RA

Renea Hicks, A/Atty General, EP Div.-TX